

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report  
are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

# CROO 1339 WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

(Do not write above this line)

**CROO  
1339**

State Well No. 145/16E-29bd  
State Permit No. \_\_\_\_\_

(1) OWNER: 40 SHOWN CROS ROADS  
Name PAUL HURAN SUBDIVISION  
Address 535 W. 5th  
City? PRINEVILLE, ORE. 97754

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
Rotary  Driven  COMMUNITY SYSTEM  
Cable  Jetted  Domestic  Industrial  Municipal   
Dug  Bored  Irrigation  Test Well  Other

(5) CASING INSTALLED: Threaded  Welded   
6 " Diam. from 7.3 ft. to 5.8 ft. Gage 2.50  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(6) PERFORATIONS: Perforated?  Yes  No.  
Type of perforator used THOROH  
Size of perforations 1/16 in. by 8 in.  
1.50 perforations from 2.8 ft. to 5.8 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
d: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
Bailer test 40 gal./min. with comp. drawdown after 2 hrs.  
Artesian flow NONE g.p.m.  
Temperature of water 56 Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION:  
Well seal—Material used CEMENT GROUT  
Well sealed from land surface to 8.5 ft. ft.  
Diameter of well bore to bottom of seal 12" in.  
Diameter of well bore below seal 10" in.  
Number of sacks of cement used in well seal 16 sacks  
How was cement grout placed? PUMPED WITH GROUT PUMP, PLACED FROM BOTTOM - UP.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? SHALLOW depth of strata 8'  
Method of sealing strata off CEMENT GROUT  
Was well gravel packed?  Yes  No Size of gravel: 1/4 M.M.S.  
Gravel placed from 2.5 ft. to 5.8 ft.

(10) LOCATION OF WELL:  
County CROOK Driller's well number 41-C  
S. E 1/4 N. 4 1/4 Section 29 T. 14S R. 16E W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

(11) WATER LEVEL: Completed well.  
Depth at which water was first found 8' ft.  
Static level 11 ft. below land surface. Date 10/15/79  
Artesian pressure NONE lbs. per square inch. Date \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing \_\_\_\_\_  
Depth drilled 58 ft. Depth of completed well 58 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	4	
BROWN CLAY	4	8	
CLAY & GRAVEL	8	9	
BROWN CLAY	9	28	12'
Med. FINE SAND w/b.	28	58	12'

Work started 10/15 1979 Completed 10/16 1979  
Date well drilling machine moved off of well 10/16 1979

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Curt Clauson Date 10/18, 1979  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 1237

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name CLAYSON Well Drilling  
(Person, firm or corporation) (Type or print)  
Address RT. 1, Box 780 Prineville, ORE.  
[Signed] Curt Clauson  
(Water Well Contractor)  
Contractor's License No. 741 Date 10/18, 1979