

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

CROO 1340
WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

CROO
1340

State Well No. 105/16E-296d

State Permit No. _____

(1) OWNER:

Name PAUL HURNS
Address 535 W. 5th
City? PRINEVILLE, OR 97754

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

COMMUNITY SYSTEM
Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 12 ft. to 60 ft. Gage 1250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used TORCH
Size of perforations 1/16 in. by 8 in.
150 perforations from 28 ft. to 60 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
1: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
Bailer test 40 gal./min. with Comp ft. drawdown after 2 hrs.
Artesian flow NONE g.p.m. _____
Temperature of water 56 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT
Well sealed from land surface to _____ ft. 25
Diameter of well bore to bottom of seal 12" in.
Diameter of well bore below seal 10" in.
Number of sacks of cement used in well seal _____ sacks 17
How was cement grout placed? pumped with
grout pump, from bottom-up
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? SHALLOW depth of strata 8
Method of sealing strata off CEMENT GROUT
Was well gravel packed? Yes No Size of gravel: 4M.M.S.
Gravel placed from 25 ft. to 60 ft.

(10) LOCATION OF WELL:

County CROOK Driller's well number 42-C
S.E. 1/4 N.43 1/4 Section 29 T.14S R.16E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 8 ft.
Static level 10 ft. below land surface. Date 10/30/79
Artesian pressure NONE lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 60 ft. Depth of completed well 60 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	4	
BROWN CLAY	4	8	
BROWN CLAY & GRAVEL	8	9	
GRAVEL			
BROWN CLAY	9	27	
Med. FINE SAND #1B	27	58	
SANDY BLACK CLAY	58	60	

Work started 10/29 1979 Completed 10/30 1979
Date well drilling machine moved off of well 10/30 1979

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Curt Clauson Date 10/31, 1979.
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1237

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name CLAYSON Well DRILLING
(Person, firm or corporation) (Type or print)
Address RT.1, Box 780 PRINEVILLE, ORE.
[Signed] Curt Clauson
(Water Well Contractor)
Contractor's License No. 741 Date 10/31, 1979