NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the	1357 LL REPORT	/ 1x 20
WATER RESOURCES DEPARTMENT. FEB 13 1986 OF	OREGON CO State Well No	14s/16E-29
SALEM, OREGON 97310 (Please type	e of print)	•
of well completion. (Do not write a	bove this line) 357 State Permit	No
(1) OWNER: 6	(10) LOCATION OF WELL:	
Name ROBERT J DARKEE	County CROK Driller's well number 5.2	
Address 3/0 5 Clay fool "	341 1/4 S41 1/4 Section Z9 T. 14 5	
- Prineville	Bearing and distance from section or subdivi	
(2) TYPE OF WORK (check):	Search direction Section of Subdivi	sion corner
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 60	_
Rotary Driven Domestic Industrial Municipal K	Static level 42 ft. below land surface. Date 2-8-78	
Cable V Jetted Industrial I	Artesian pressure lbs. per square inch. Date	
, CASING INSTALLED: Threaded □ Welded M	155. per squi	Te men. Date
CASING INSTALLED: Threaded Welded Wel	(12) WELL LOG: Diameter of well	below casing
"Diam from ft. to ft. Gage ft. Gage ft. Gage ft. Gage ft. Gage	Depth drilled 200 ft. Depth of completed well 175 ft.	
"Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,	
	with at least one entry for each change of form	ation. Report each change in
) PERFORATIONS: Perforated? Yes \(\square\) No.	position of Static Water Level and indicate pri	ncipal water-bearing strata.
Type of perforator used Cutting That	MATERIAL	From To SWL
Size of perforations in. by in.	Top Soil	0 1
perforations from 140 ft. to 144 ft.	Clay & Gravel Brown	1 12
perforations from ft. to ft.	Clay & Sand Brown	12 15
perforations from ft. to ft.	Clay Brown Hard	38 61
(7) SCREENS: Well screen installed? Yes No	Gravel & Sand Clay Brown	61 80
Manufacturer's Name	Sand Brown	80 95
Type Model No.	Clay Bancl Gray	95 140
Diam. Slot size Set from ft. to ft.	Clay Stone Green, Ked	140 200 42
Diam, Slot size Set from ft. to ft.	(Water Bearing)	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? ☐ Yes 承 No If yes, by whom?		
Viold:		
gai./mm. with ft. drawdown after hrs.		
" " "		
112 120 millon		
Artesian flow g.p.m. gal./min. with 70 ft. drawdown after hrs.		
aperature of water Depth artesian flow encountered	2 4/ 100	1 1 2 20
The second secon	Work started 7 - 1978 Complete	19/3
(9) CONSTRUCTION:	Date well drilling machine moved off of well	2-8 19.78
Well seal-Material used CemenT	Drilling Machine Operator's Certification	
Well sealed from land surface toft.	This well was constructed under my Materials used and information reported	direct supervision.
Diameter of well bore to bottom of seal in.	best knowledge and belief.	
Diameter of well bore below sealinin	[Signed] Novel falch	Date 2 8 , 19/
How was cement grout placed? MIXED UP PUMP	Drilling Machine Operator's License No.	764
From Botton up.		
/	Water Well Contractor's Certification:	
	This well was drilled under my jurisdiction and this report is	
Was a drive shoe used? ⚠️Yes ☐ No Plugs Size: location ft.	true to the best of my knowledge and belief. Name 1905 110 110 110 110 110 110 110 110 110 1	
Did any strata contain unusable water? Yes No	Person, tim or corporation) (Type or print)/	
Type of water? depth of strata	Address Address	MINPUILLE
Method of sealing strata off	[Signed] A of this E. Co	
Was well gravel packed? [] Yes 🔀 No Size of gravel:	(Water Well Cont	ractor)
Gravel placed from ft. to ft.	Contractor's License No. 6 3. Date C	1- S 19/8