The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

GR00 1399

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED JUL 20 1976 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. .....

State Permit No. 14S/16E-30

970130

(1) OWNER:

Name Frank Dosser

Address P.O. Box 185 Kingsley Or. KIRKLAND

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐

☒ Jetted ☐

☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐

Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 20 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.

Type of perforator used TORCH

Size of perforations 1/8 in. by 6 in.

72 perforations from 56 ft. to 68 ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

ld: gal./min. with ft. drawdown after hrs.

" " " "

" approx " " "

Bailer test 20 gal./min. with 0 ft. drawdown after 1 hrs.

esian flow g.p.m.

emperature of water 58° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used NEAT CEMENT

Well sealed from land surface to 18 ft.

Diameter of well bore to bottom of seal 12 in.

Diameter of well bore below seal 8 in.

Number of sacks of cement used in well seal — sacks

Number of sacks of bentonite used in well seal — sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons of water — lbs./100 gals.

Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Crook Driller's well number

¼ ¼ Section 30 T. 14S R. 16E W.M.

Bearing and distance from section or subdivision corner

Lot 10 - Buckaroo Acres

(11) WATER LEVEL: Completed well.

Depth at which water was first found 49 ft. ft.

Static level 44 ft. below land surface. Date 6-20-76

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing

Depth drilled ft. Depth of completed well ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
TOPSOIL SANDY	0	6	
CLAY BROWN W/ GRAVEL	6	12	
CLAY BROWN W/ SAND	12	25	
CLAY BROWN	25	34	
SAND BROWN	34	70	44

Work started 6-12 1976 Completed 6-20 1976

Date well drilling machine moved off of well 6-21 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Ron Scanlon (Drilling Machine Operator) Date 6-20, 1976

Drilling Machine Operator's License No. 348

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name RON SCANLON WELL DRILLING (Person, firm or corporation) (Type or print)

Address 721 W 2nd St. PRINEVILLE

[Signed] Ron Scanlon (Water Well Contractor)

Contractor's License No. 540 Date 6-20, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-111