

Contractor's License No. _____ Date 2-5 1981

December 18, 1981

RECEIVED

DEC 23 1981

WATER RESOURCES DEPT
SALEM, OREGON

Mr. A. M. Petska
Water Resources Department
Mill Creek Office Park
555 13th St. NE
Salem, Oregon 97310

Dear Mr. Petska:

RE: Well Log

In November of 1980, we filed an application for water rights. Our application was filed and assigned number G-10003. In our water well report we did not complete the well test at that time of construction. As of now, these tests have been completed. They are as follows:

WELL # 1: A well pump test was made with a yield of 225 gallons per minute with a draw down of seven feet after 24 hours.

WELL # 2: A well pump test was made with a yield of 250 gallons per minute with a draw down of eight feet after 24 hours.

WELL # 3: A well pump test was made with a yield of 150 gallons per minute, with a draw down of eight feet after 24 hours.

WELL #4: A well pump test was made with a yield of 300 gallons per minute with a draw down of seven feet.

I hope this is the information that is needed to complete the necessary well log. Thankyou for your patience.

Sincerely,

Wayne P. Singhose

Wayne P. Singhose
62500 County Line Rd.
Bend, Oregon 97701

Reference File Number G-10003