NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
JUN 16 1977
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CROO 1585
CROO 1585

State Well No. 14S/16E-33C
State Permit No.

(1) OWNER:
Name Randy McAlister
Address 2021 E. Laughlin Rd Prineville

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:
Threaded ☐ Welded ☒
6 " Diam. from 0 ft. to 48 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Cutting Torch
Size of perforations 1/8 in. by 1" in.
40 perforations from 28 ft. to 48 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 13 gal./min. with 5 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed?

Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: Pea
Gravel placed from 28 ft. to 48 ft.

(10) LOCATION OF WELL:
County Crook Driller's well number 3
SE. ¼ SW ¼ Section 33 T. 14S R. 16E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 28 ft.
Static level 15 ft. below land surface. Date
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 49 ft. Depth of completed well 48 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. **Report each change in position of Static Water Level and indicate principal water-bearing strata.**

MATERIAL	From	To	SWL
Top Soil	0	1	
Clay Brown	1	15	
Clay Yellow	15	21	
Clay & Sand	21	48	15
Water Bearing			

Work started 5-4 19 77 Completed 5-5 19 77
Date well drilling machine moved off of well 5-5 19 77

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Richard C. Parker Date 5-28, 19 77
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1025

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Charles M. Saylor Drilling Co.
(Person, firm or corporation) (Type or print)
Address 151 Fairbanks Ave. Klamath Falls
[Signed] Charles M. Saylor
(Water Well Contractor)
Contractor's License No. 614 Date 6-14, 19 77

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119