

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

CROO
1727

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

MAR 11 1976 State Well No.

155/14K-3

WATER RESOURCES DEPT. Permit No.

SALEM, OREGON G-7113E G-7524

(1) OWNER: Twin Lakes Ranchs

Name Dick Davis
Address 7100 S.W. Hampton Suite 103
Tigard, Oregon 97223

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded

8" Diam. from +1 ft. to 89 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 20 gal./min. with 0 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 70 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 39 sacks
Number of sacks of bentonite used in well seal None sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Crook Driller's well number
SW 1/4 SW 1/4 Section 3 T. 15 S R. 14 E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 234 ft.
Static level 234 ft. below land surface. Date 3/5/76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 276 ft. Depth of completed well 276 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|--------------------------------|------|-----|-----|
| Topsoil | 0 | 1/2 | |
| Mild Pinhole Lava - Gray | 1/2 | 6 | |
| Cong. - Brown | 6 | 50 | |
| Lava - Black and Broken | 50 | 90 | |
| Basalt - Hard, Black | 90 | 130 | |
| Cinders and Lava - Red | 130 | 142 | |
| Sandstone - Lt. Brown | 142 | 155 | |
| Sand - Brown | 155 | 205 | |
| Sandstone - Brown | 205 | 231 | |
| Shale - Gray, Broken Water/B | 231 | 255 | 234 |
| Sand - Black and Lava - Broken | 255 | 276 | |

Work started 11/24/1975 Completed 3/5/ 1976

Date well drilling machine moved off of well 3/9/ 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Edward M. Ellett Date 3/9/ 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1019

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Davidson Drilling Inc. (Type or print)
(Person, firm or corporation)

Address 626 NW Pershall Way Redmond, Oregon 97756

[Signed] W. Gordon Davidson
(Water Well Contractor)

Contractor's License No. 548 Date 3/9/ 1976