NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 21 1972 STATE ENGINEER SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CROO 2050

State Well No. 15S/16E-4

State Permit No.

(1) OWNER:
Name Robert E. Cleary
Address 757 Willowdale Prineville, Ore 97754

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 25 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used cutting torch
Size of perforations 1/16 in. by 6 in.
16 perforations from 20 ft. to 25 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 10 gal./min. with 7 ft. drawdown after 1 hrs.
Artesian flow none g.p.m.
Temperature of water 56 Depth artesian flow encountered none ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Crook Driller's well number 171
¼ ¼ Section 4 T. 15S R. 16E W.M.
Bearing and distance from section or subdivision corner
N.E 1/4 of the S.W. 1/4

(11) WATER LEVEL: Completed well.
Depth at which water was first found 20 ft.
Static level 7 ft. below land surface. Date 5/9/72
Artesian pressure none lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 25 ft. Depth of completed well 25 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
top soil	0	4	
gravel	4	11	
soft gray clay	11	20	
gravel water bearing	20	23	7

Work started 5/9 1972 Completed 5/9 1972
Date well drilling machine moved off of well 5/9 1972

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Archie Fox (Drilling Machine Operator) Date 5/12, 1972
Drilling Machine Operator's License No. 389

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Archie Fox, Well Drilling (Person, firm or corporation) (Type or print)
Address Rt. 1 Box 1149 Prineville, Ore 97754
[Signed] Archie Fox (Water Well Contractor)
Contractor's License No. 389 Date 5/12, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119