RECEIVED
MAR 2 1966
STATE ENGINEER
SALEM, OREGON

CR00 2088

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 15/16-4N

State Permit No.

(1) OWNER:
Name Archie Fox
Address 2277 Lincoln Rd
Gervais

(2) LOCATION OF WELL:
County Marion Driller's well number 10
SW ¼ SW ¼ Section 4 T. 15 S R. 16 E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
6 " Diam. from 0 ft. to 140 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Cutting Torche
Size of perforations 1/16 in. by 6 in.
30 perforations from 130 ft. to 140 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite
Depth of seal 90 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 3 ft. below land surface Date 2/14/66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 20 gal./min. with 240 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 65 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 250 ft. Depth of completed well 250 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Pumice Sand (Brown)	0	20
Clay (Brown)	20	30
Gravel (medium)	30	35
Clay (Brown)	35	60
gravel (medium)	60	65
Clay (yellow)	65	90
Sand & Gravel	91	95
Clay, (light green)	95	145
Bedrock, soapy, stone (yellow)	145	150
Clay (yellow)	150	245
broken soapy (stone) (yellow)	245	250
water at →	30	35
	60	65
245 to 250 ←	96	95
	145	150

Work started 2/7/1966 Completed 2/14/1966
Date well drilling machine moved off of well 2/15/1966

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Archie Fox (Person, firm or corporation) (Type or print)
Address 2277 Lincoln, Rd. Gervais
Drilling Machine Operator's License No. 389
[Signed] Archie Fox (Water Well Contractor)
Contractor's License No. 744 Date 2/27, 1966

(USE ADDITIONAL SHEETS IF NECESSARY)