NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CROO 2102

State Well No. 15s/16E-5ba

State Permit No.

(1) OWNER:
Name OLAN FORD
Address #11 Hill Rd. Prineville, ORE.

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
D[ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [X]

(5) CASING INSTALLED:
Threaded [ ] Welded [X]
6 " Diam. from +1 ft. to 35 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? [X] Yes [ ] No
Type of perforator used TORCH
Size of perforations 1/16 in. by 8 in.
50 perforations from 25 ft. to 35 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
[illegible]: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 20 gal./min. with 9 ft. drawdown after 1 hrs.
Artesian flow NONE g.p.m.
Temperature of water 56 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT GROUT
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 15 sacks
How was cement grout placed? CEMENT GROUT PUMPED WITH GROUT PUMP, PLACED FROM BOTTOM UPWARD

Was a drive shoe used? [ ] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [X] Yes [ ] No Size of gravel: 1/4 MINUS
Gravel placed from 25 ft. to 35 ft.

(10) LOCATION OF WELL:
County CROOK Driller's well number 51-C
NE ¼ NW ¼ Section 5 T. 15S R. 16E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 15 ft.
Static level 10 ft. below land surface. Date 2/28/80
Artesian pressure NONE lbs. per square inch. Date —

(12) WELL LOG:
Diameter of well below casing —
Depth drilled 35 ft. Depth of completed well 35 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	5	
GRAVEL & CLAY	5	8	
BROWN CLAY	8	15	
MED. FINE SAND	15	30	10
FINE BLACK SAND	30	35	10

RECEIVED
MAR 25 1980
WATER RESOURCES DEPT.
SALEM, OREGON

Work started 2-28 1980 Completed 2-29 1980
Date well drilling machine moved off of well 2-29 1980

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Curt Clauson Date 3-3, 1980
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1237

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name CLAUSON WELL DRILLING
(Person, firm or corporation) (Type or print)
Address RT. 1, BOX 780 PRINEVILLE, ORE.
[Signed] Curt Clauson
(Water Well Contractor)
Contractor's License No. 741 Date 3-3, 1980

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119