NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

CROO 2106

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
JUL 9 - 1976
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 15S/16E-5
State Permit No. 22

(1) OWNER:
Name Ross Payne
Address 1385 Combs Flat Rd. Prineville

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☑
6 " Diam. from +2 ft. to 35 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? ☑ Yes ☐ No.
Type of perforator used Torch
Size of perforations 6 in. by 1/8 in.
108 perforations from 18 ft. to 36 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 40 gal./min. with NO ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 50 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal — sacks
Number of sacks of bentonite used in well seal 5 sacks
Brand name of bentonite Vol Clay
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☑ Yes ☐ No Size of gravel: 3/4 -
Gravel placed from 18 ft. to 36 ft.

(10) LOCATION OF WELL:
County Crook Driller's well number 22
¼ ¼ Section 5 T. 15S R. 16E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 20 ft.
Static level 15 ft. below land surface. Date 7/1/76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6"
Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Sandy Topsoil	0	1	
Brown Sand	1	20	15
Sand and Gravel	20	35	
Brown clay	35	36	

Work started 7/1 19 76 Completed 7/2 19 76
Date well drilling machine moved off of well 7/2 19 76

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Darrell Maphet (Drilling Machine Operator) Date 7/2, 19 76
Drilling Machine Operator's License No. 768

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Maphet Well Drilling (Person, firm or corporation) (Type or print)
Address P.O.R. Box 198 Prineville
[Signed] Darrell Maphet (Water Well Contractor)
Contractor's License No. 584 Date 7/2, 19 76

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119