NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON, 97310, within 30 days from the date of well completion.

RECEIVED NOV 28 1969 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON (Please type or print) (Do not write above this line)

CROO 2107

State Well No. 15/16-5

State Permit No.

(1) OWNER:

Name Octave D. Precourt

Address 785 Combs Flat Rd. Prineville, Ore

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 30 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☒ Yes ☐ No.

Type of perforator used Cutting torch

Size of perforations 1/16 in. by 6 in.

40 perforations from 20 ft. to 30 ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 6 ft. below land surface Date 10/23

Artesian pressure no lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 20 gal./min. with 5 ft. drawdown after 1 hrs.

Artesian flow no g.p.m. Date

Temperature of water 56 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Bentonite

Depth of seal 20 ft.

Diameter of well bore to bottom of seal 8 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☐ Yes ☒ No

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Crook Driller's well number 38

¼ ¼ Section 5 T. 15s R. 16e W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 30 ft. Depth of completed well 30 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
top soil	0	6	
soft clay	6	20	6
sand & fine gravel	20	30	6

Work started 10/22 1969 Completed 10/23 1969

Date well drilling machine moved off of well 10/24 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Archie Fox (Drilling Machine Operator) Date 11/24, 1969

Drilling Machine Operator's License No. 389

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Archie Fox Well Drilling (Person, firm or corporation) (Type or print)

Address 2277 Lincoln Rd. Prineville, Ore

[Signed] Archie Fox (Water Well Contractor)

Contractor's License No. 444 Date 11/24, 1969.

(USE ADDITIONAL SHEETS IF NECESSARY)