NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
SEP 23 1969
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CROO 2108

State Well No. 15/16 5

State Permit No.

(1) OWNER:
Name Neil Wyse
Address 750 Helmton Rd Prineville Oregon

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:
Threaded [ ] Welded [X]
6" Diam. from 0 ft. to 43 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? [X] Yes [ ] No
Type of perforator used FACTORY
Size of perforations 1/4 in. by 2" in.
114 perforations from 32 ft. to 42 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

5 19 6 114

(7) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 14 ft. below land surface Date 9/16/69
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" aprox " " "
Bailer test 20 gal./min. with ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 57 Was a chemical analysis made? [ ] Yes [X] No

(10) CONSTRUCTION:
Well seal—Material used Bentonite & Cuttings
Depth of seal 28 ft. ft.
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? [ ] Yes [X] No Depth
Was a drive shoe used? [ ] Yes [X] No
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [X] Yes [ ] No Size of gravel: 1/4 minus
Gravel placed from 28 ft. to 43 ft.

(11) LOCATION OF WELL:
County CROOK Driller's well number
1/4 1/4 Section 5 T. 15 R. 16 E W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG:
Diameter of well below casing
Depth drilled 43 ft. Depth of completed well 43 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Sandy top soil	0	3	
Brown Sand + clay	3	21	14
Brown Course sand	21	38	
Blue silt	38	43	

Work started 9/15 1969 Completed 9/16 1969
Date well drilling machine moved off of well 9/16 1969

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Nick Akins (Drilling Machine Operator) Date 9/20, 1969
Drilling Machine Operator's License No. 249

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Akins Well Drilling (Person, firm or corporation) (Type or print)
Address P.O. Box 264
[Signed] Nick Akins (Water Well Contractor)
Contractor's License No. 260 Date 9/20, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)