NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CROO 2118

State Well No. 15S/16E-5cc

State Permit No.

RECEIVED
OCT 27 1977
WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:
Name Charlie Moore
Address 1395 Lynn Blvd Prineville

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED: Threaded [ ] Welded [X]
6 " Diam. from 0-1 ft. to 30 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? [X] Yes [ ] No
Type of perforator used Cutting Tours
Size of perforations 1/2 in. by 8 in.
20 perforations from 30 ft. to 20 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 1.5 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonit
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? Poured Down Dry

Was a drive shoe used? [ ] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Crook Driller's well number 31
SW ¼ SW ¼ Section 5 T. 15S R. 16E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 20 ft.
Static level 8 ft. below land surface. Date 10-21-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 30 ft. Depth of completed well 30 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
topsoil	0	1	
Clay Brown	1	6	
Clay & Gravel	6	15	
Clay Brown	15	20	
Clay Sand & Gravel Brown Water Bearing	20	30	8

Work started 10-20 19 77 Completed 10-20 19 77
Date well drilling machine moved off of well 10-21 19 77

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Rodney C. Gale (Drilling Machine Operator) Date 10-26, 1977
Drilling Machine Operator's License No. 1075

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Rod's Well Drilling (Person, firm or corporation) (Type or print)
Address POB 351 Prineville
[Signed] Rodney C. Gale (Water Well Contractor)
Contractor's License No. 663 Date 10-26, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119