NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
NOV 3 1966
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

CROO 2125

State Well No. 15/16-5
State Permit No.

(1) OWNER:
Name Milton Shrum
Address 397 W. 3rd Prineville Oregon

(2) LOCATION OF WELL:
County Crook Driller's well number
¼ N.E ¼ Section 5 T. 15S R. 16E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
[redacted] Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
6" Diam. from 3+ ft. to 227 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Torch
Size of perforations ¼ in. by 6" in.
69 perforations from 213 ft. to 226 ft.
perforations from ft. to ft.
[redacted] perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? ☐ Yes ☐ No
Manufacturer's Name
[redacted] Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement
Depth of seal 23 ft. Was a packer used? No
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel: —
Gravel placed from — ft. to — ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? — depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level ft. below land surface Date
Artesian pressure 10 lbs. per square inch Date 10/4/66

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 135 g.p.m. Date 10/4/66
Temperature of water 56 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing —
Depth drilled 227 ft. Depth of completed well 227 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sandy Top soil	0	4
Sand & Gravel	4	23
Blue silt & fine black sand	23	138
Blue clay (soft)	138	221
Blue Clay & gravel all colors	221	227

Work started 9/26 1966 Completed 10/4 1966
Date well drilling machine moved off of well 10/4 1966

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Dick Akins Well Drilling (Person, firm or corporation) (Type or print)
Address P.O. Box 264 Prineville Oregon
Drilling Machine Operator's License No. 249-348
[Signed] Dick Akins (Water Well Contractor)
Contractor's License No. 260 Date 10/4, 1966

(USE ADDITIONAL SHEETS IF NECESSARY)