NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

CROO 2126

WATER WELL REPORT
STATE OF OREGON

(Please type or print)
(Do not write above this line)

RECEIVED
NOV - 4 1977
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 15S/16E-5ba
State Permit No.

(1) OWNER:
Name Wesley L Craig
Address Mill Ck Rd. Prineville

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED:
Threaded [ ] Welded [X]
6 " Diam. from 0 ft. to 20 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? [ ] Yes [X] No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 13 gal./min. with 130 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 4 sacks
How was cement grout placed? Poured Down Drg
Was a drive shoe used? [ ] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Crook Driller's well number 29
NE ¼ NW ¼ Section 5 T. 15S R. 16E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 300 ft.
Static level 130 ft. below land surface. Date 10-27-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 310 ft. Depth of completed well 310 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	1	
Rock Clay Brown	1	10	
Clay Yellow	10	14	
Rock Gray Hard	14	25	
Clay Stone Brown	25	55	
Rock Gray Hard	55	105	
Clay Stone Green	105	140	
Rock Gray Hard	140	170	
Rock Broken Brown	170	190	
Rock Gray Hard	190	200	
Clay Stone Blue Green	200	295	
Clay Stone Blue Green Hard (Water Bearing)	295	310	130

Work started 9-19 1977 Completed 10-28 1977
Date well drilling machine moved off of well 10-28 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Rodney C. Eck (Drilling Machine Operator) Date 11-1, 1977
Drilling Machine Operator's License No. 1067 1075

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Rod's Well Drilling (Person, firm or corporation) (Type or print)
Address PO Box 351 Prineville
[Signed] Rodney C. Eck (Water Well Contractor)
Contractor's License No. 663 Date 11-1, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119