RECEIVED

MAY 20 1987

WATER RESOURCES DEPT.
SALEM, OREGON

CROO 2142

WATER WELL REPORT
STATE OF OREGON

State Well No. 15s/16E-6aa

State Permit No. .....

Per WM: Location is T15s, R16E-6aa

(1) OWNER:

Name The Prineville Bank

Address 422 N. Beaver

City Prineville, Or. State 97754

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air ☐ Driven ☐
Rotary Mud ☐ Dug ☐
C[illegible] ☒ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☒ Reinjection ☐

(5) CASING INSTALLED: Steel ☒ Plastic ☐ Threaded ☐ Welded ☒

6 " Diam. from +1 ft. to 25 ft. Gauge .250

..... " Diam. from ..... ft. to ..... ft. Gauge .....

[illegible]LINER INSTALLED:

— " Diam. from — ft. to — ft. Gauge —

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No

Type of perforator used Cutting Torch

Size of perforations 1/16 in. by 6 in.

40 perforations from 18 ft. to 25 ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name .....

Type ..... Model No. .....

Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.

Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

Air test gal./min. with drill stem at ft. hrs.

Bailer test 15 gal./min. with 3 ft. drawdown after 1 hrs.

Artesian flow none g.p.m. —

Temperature of water 56 Depth artesian flow encountered — ft.

(9) CONSTRUCTION: Special standards: Yes ☐ No ☒

Well seal—Material used Cement

Well sealed from land surface to 18 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 4 sacks

How was cement grout placed? Tramie pipe

Was pump installed? NO Type — HP — Depth — ft.

Was a drive shoe used? ☐ Yes ☒ No Plugs — Size: location — ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of Water? — depth of strata —

Method of sealing strata off —

Was well gravel packed? ☐ Yes ☒ No Size of gravel: —

Gravel placed from — ft. to — ft.

(10) LOCATION OF WELL:

County Crook Driller's well number 0030

S.E. ¼ S.E. ¼ Section 31 T. 14S R. 16E W.M.

Tax Lot # 11100 Lot Blk Subdivision

Address at well location: 422 N Beaver Prineville, Or. 97754

(11) WATER LEVEL: Completed well.

Depth at which water was first found 15 ft.

Static level 8 ft. below land surface. Date 5/6/87

Artesian pressure none lbs. per square inch. Date —

(12) WELL LOG: Diameter of well below casing 6

Depth drilled 25 ft. Depth of completed well 25 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	3	
Brown Clay	3	12	
Gravel (Water Bearing)	12	25	8

Work started 5/6 1987 Completed 5/6 1987

Date well drilling machine moved off of well 5/6 1987

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Archie Fox (Drilling Machine Operator) Date 5/8, 1987

Drilling Machine Operator's License No. 389

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Archie Fox Well Drilling (Person, firm or corporation) (Type or print)

Address P.O. Box 246 Prineville, Or. 97754

[Signed] Archie Fox (Water Well Contractor)

Contractor's License No. 444 Date 5/8, 1987

ARCHIE FOX WELL DRILLING
P.O. BOX 246
PRINEVILLE, OREGON 97754

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12658-690