WATER WELL REPORT
STATE OF OREGON

CR00 2145

RECEIVED
JUN 2 1986
WATER RESOURCES DEPT
SALEM, OREGON

RECEIVED
APR 1 1986
WATER RESOURCES DEPT
SALEM, OREGON

State Well No. 15s/16E-6da

State Permit No.

(1) OWNER:
Name Albert Stewart
Address 355 So main
City Prineville State Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☐ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☒ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: ☐ Withdrawal ☐ Reinjection ☐

(5) CASING INSTALLED:
Steel ☒ Threaded ☐ Plastic ☐ Welded ☒
6 " Diam. from 0 ft. to 22 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used
Size of perforations 1/16 in. by 6 in.
25 perforations from 18 ft. to 22 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
Air test gal./min. with drill stem at ft. hrs.
Bailer test 15 gal./min. with 5 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 56 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Special standards: ☐ Yes ☐ No ☒
Well seal—Material used Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of ~~cement~~ used in well seal Bentonite 5 sacks
How was ~~cement~~ grout placed? Drop Bentonite
(Tremie Pipe)
Was pump installed? yes Type jet HP ½ Depth 20 ft.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Crook Driller's well number 007
NE ¼ SE ¼ Section 6 T. 15 S R. 16 E W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 355 So Main
Prineville, Ore.

(11) WATER LEVEL: Completed well.
Depth at which water was first found 10 ft.
Static level 3 ft. below land surface. Date 3/11/86
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 22 ft. Depth of completed well 22 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	3	
gravel & clay	3	10	
gravel (water bearing)	10	13	3
gravel & clay	13	18	3
gravel (water Bearing)	14	22	3

Work started 3/11 19 86 Completed 3/12 19 86
Date well drilling machine moved off of well 3/12 19 86

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Archie Fox (Drilling Machine Operator) Date 3/21, 19 86
Drilling Machine Operator's License No. 389

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Archie Fox, Well Drilling (Person, firm or corporation) (Type or print)
Address P.O. Box 246 Prineville Ore.
[Signed] Archie Fox (Water Well Contractor)
Contractor's License No. 444 Date 3/21, 19 86

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12658-690