

WATER WELL REPORT  
STATE OF OREGON

RECEIVED

JUN 29 1987

State Well No. 153/16E-100  
State Permit No.

CROO  
2163

WATER RESOURCES DEPT.

SALEM, OREGON

(1) OWNER:

Name First Interstate Bank  
Address P.O. Box 520  
City Pineville State Or. 97754

(10) LOCATION OF WELL:

County Crook Driller's well number 0032  
NE 1/4 NE 1/4 Section 6 T. 15 S R. 16 E W.M.  
Tax Lot # Lot Blk Subdivision

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air  Driven   
Rotary Mud  Dug   
C  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other   
Thermal: Withdrawal  ReInjection

(5) CASING INSTALLED:

Steel  Plastic   
Threaded  Welded   
6" Diam. from 1+ ft. to 30 ft. Gauge 250  
" Diam. from ft. to ft. Gauge

(6) LINER INSTALLED:

" Diam. from ft. Gauge

(6) PERFORA

Type of perforator  Yes  No  
Size of perforations Use = 0+  
ft. to 30 ft.  
ft. to ft.  
ft. to ft.

(7) SCREEN

Manufacturer's Name  No  
Type Model No.  
Diam. Slot Size Set from ft. to ft.  
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Doulter  
50 gal./min. with 10 ft. drawdown after 2 hrs.  
Air test gal./min. with drill stem at ft. hrs.  
Bailer test 40 gal./min. with 7 ft. drawdown after 1 hrs.  
Artesian flow no g.p.m.  
Temperature of water 56 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes  No

Well seal—Material used Cement  
Well sealed from land surface to 18 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 4 sacks  
How was cement grout placed? Trench filler

Was pump installed? no Type HP Depth ft.  
Was a drive shoe used?  Yes  No Plugs Size location ft.  
Did any strata contain unusable water?  Yes  No  
Type of Water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: ft.  
Gravel placed from ft. to ft.

Address at well location:

220 W Third St.  
Pineville Or. 97754

(11) WATER LEVEL: Completed well.

Depth at which water was first found 18 ft.  
Static level 8 ft. below land surface. Date 6/2/87  
Artesian pressure no lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"  
Depth drilled 30 ft. Depth of completed well 30 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	4	
Gravel & Clay	4	18	
Gravel (water-bearing)	18	30	8

Work started 6/3 19 87 Completed 6/3 19 87  
Date well drilling machine moved off of well 6/3 19 87

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Archie Fox Date 6/26, 1987  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 389

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Archie Fox, Well Drilling  
(Person, firm or corporation) (Type or print)

Address P.O. Box 246 Pineville Ore

[Signed] Archie Fox  
(Water Well Contractor)

Contractor's License No. 444 Date 6/26, 19 87

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
SALEM, OREGON 97310  
within 30 days from the date of well completion.

SP\*12658-690