NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the CROU

WATER RESOURCES DEPARTMENT SALEM, OREGON 97310 SALEM, OREGON 81040 within 30 days from the date of well completion.

## WATER WELL REPORT

## STATE OF OREGON

(Please type or print)

(Do not write above this line)

State	Well	No.	ISSILVE	٠	10 0	ic

State	Well No.	"IOSII6E	- wae
State	Permit 7	νo	

(1) OWNER:	(10) LOCATION OF WELL:			
Name MARTIN HOWARD	County CROOK Driller's well number 137			
Address OCHO(O HIWAY	S(1) 14 SE 14 Section 10 T. 15 S R. 16 E W.M.			
PRINEVILLE OPEGON 97754	Bearing and distance from section or subdivision corner			
(2) TYPE OF WORK (check):				
New Well 🛕 Deepening 🗌 Reconditioning 🗍 Abandon 🗍				
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 280 ft.			
Rotary   Driven   Domestic   Industrial   Municipal	Static level 127 ft. below land surface. Date 7-6-7			
Dug Bored Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date			
CASING INSTALLED: Threaded ☐ Welded 🖄	(12) WELL LOG: Diameter of well below casing 6			
"Diam. from	Depth drilled 500 ft. Depth of completed well 500 ft.			
ft. toft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,			
PERFORATIONS: Perforated?   Yes No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.			
Type of perforator used	MATERIAL From To SWL			
Size of perforations in. by in.	SANDY TOP SOIL O 1			
perforations from	YELLOW CLAY & BOLLDERS 1 13			
perforations from ft. to ft.	VELLOW CLAY 13 60			
perforations fromft. toft.	HARD GRAY CLAYSTONE 60 260			
(7) SCREENS: Well screen installed?   Yes X No	HARD BLUE - GREEN CLAYSTONE 260 490			
Manufacturer's Name	HARD RED POUR 490 500			
Type Model No				
Diam. Slot size Set from ft. to ft.				
Diam. Slot size Set from ft. to ft.				
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	RECEIVED			
Was a pump test made?  Yes No If yes, by whom?	JUL 30 1979			
Yield: gal./min. with ft. drawdown after hrs.				
n n	WATER RESOURCES DEPT			
AIP I I FT	SALEM, OREGON			
Bailer test. 30 gal./min. with Oft. drawdown after hrs.				
Artesian flow g.p.m.				
nperature of water 76 Depth artesian flow encountered ft.	Work started 7-4 19 79 Completed 7-6 19 79			
(9) CONSTRUCTION:	Date well drilling machine moved off of well 7-6 1979			
Well seal—Material used CEMENT	Drilling Machine Operator's Certification:			
Well sealed from land surface to 19 ft.	This well was constructed under my direct supervision.			
Diameter of well bore to bottom of seal	Materials used and information reported above are true to my best knowledge and belief.			
Diameter of well bore below seal in.	[Signed] Dane Marshet Date 7-24, 1979.			
Number of sacks of cement used in well seal 10 sacks	(Drilling Machine Operator)			
How was cement grout placed? PUMPED	Drilling Machine Operator's License No			
	Water Well Contractor's Certification:			
The second secon	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Was a drive shoe used?   Yes  No Plugs Size: location ft	Name MAPHET WELL DRILLING			
Did any strata contain unusable water?   Yes No	(Person, firm or corporation) (Type or print)			
Type of water? depth of strata	Address PLL 500 DAUIS LOAD PRINEUKLE			
Method of sealing strata off	[Signed] Land Market			
Was well gravel packed? ☐ Yes 🖟 No Size of gravel:	(Water Well Contractor)			
Gravel placed from ft. to ft.	Contractor's License No. 584 Date 7-24, 1979			