NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

CROO 2366

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED FEB 26 1973 STATE ENGINEER SALEM, OREGON

State Well No. 15S/16E-29 da
State Permit No.

(1) OWNER:
Name Richard D. Akins
Address P.O. Box 264 Prineville Oregon

(2) TYPE OF WORK (check):
New Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☐
6" Diam. from +18" ft. to 56 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Newton
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 20 gal./min. with 20 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 58 Depth artesian flow encountered — ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 56 ft ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6" in.
Number of sacks of cement used in well seal 6 sacks
Number of sacks of bentonite used in well seal — sacks
Brand name of bentonite —
Number of pounds of bentonite per 100 gallons of water — lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs — Size: location — ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? — depth of strata —
Method of sealing strata off —
Was well gravel packed? ☐ Yes ☒ No Size of gravel: —
Gravel placed from — ft. to — ft.

(10) LOCATION OF WELL:
County Crook Driller's well number
N.E. ¼ S.E. ¼ Section 29 T. 15S R. 16E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 208 ft.
Static level 170 ft. below land surface. Date 3-29-72
Artesian pressure — lbs. per square inch. Date —

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 350 ft. Depth of completed well 350 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Brown Sandstone	250	350	170
Reamed & added 16 ft of casing & cemented in.			

Work started 3-20 1972 Completed 3-28 1972
Date well drilling machine moved off of well 3-29 1972

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Dick Akins + Darrell M. Date 3-30, 1972
(Drilling Machine Operator)
Drilling Machine Operator's License No. 249 + 768

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Dick Akins Well Drilling (Person, firm or corporation) (Type or print)
Address P.O. Box #264, Prineville, Ore. 97754
[Signed] Dick Akins (Water Well Contractor)
Contractor's License No. 260 Date 3-30, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119