

NC

RECEIVED

JUL 9 1965

WATER WELL REPORT

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON, within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON (Please type or print)

3774 1964 Jan 22 10
CROOK 2765

State Well No. 16/17-33 L
State Permit No.

(1) OWNER:

Name MELVIN BILYEN & HOWARD FALL
Address 1000 HACIENDA LANE
PRINEVILLE OREGON

(2) LOCATION OF WELL:

County CROOK Driller's well number
NE 1/4 S.W. 1/4 Section 33 T. 16S R. 17E. W.M.
Bearing and distance from section or subdivision corner
Jasper Knolls Home Sites
Lot 26 Block 2

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from -3 ft. to 42 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE
Depth of seal 40 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 166 ft. below land surface Date 6-8-64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Baller test 30 gal./min. with 30 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water 54° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 204 ft. Depth of completed well 204 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SANDY CLAY & BROKEN ROCK	0	2
SHATTERED SHALE ROCK	2	38
BROWN Grey hard rock	38	143
Reddish hard rock	143	176
Grey rock medium	176	204

Work started 5-20 1964. Completed 6-7 1964
Date well drilling machine moved off of well 6-8 1964

(13) PUMP:

Manufacturer's Name FAIRBANKS MORSE
Type: SUBMERSIBLE H.P. 3 horse

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

DICK AKINS WELL DRILLING
NAME P. O. BOX 284 (Type or print)
Address PRINEVILLE, OREGON

Drilling Machine Operator's License No. 249
[Signed] Dick Akins (Water Well Contractor)
Contractor's License No. 260 Date 7-7 1965