

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date
 of well completion.

WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)

CROO
2792

State Well No. 175/17E-4 ca
 State Permit No. _____

(1) OWNER:

Name Joe Batters
 Address 1550 Lopez Rd
Prineville Oregon

(2) LOCATION OF WELL:

County Crater Driller's well number _____
SW 1/4 NE 1/4 Section 4 T. 17S R. 17E W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 20 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used _____
 Size of perforations in. by _____ in.
 perforations from _____ ft. to _____ ft.
 perforations from _____ ft. to _____ ft.
 perforations from _____ ft. to _____ ft.
 perforations from _____ ft. to _____ ft.
 perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite + Puddle Clay
 Depth of seal 19 ft. Was a packer used? Yes No
 Diameter of well bore to bottom of seal 12 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 41 ft. below land surface Date 10/11/63
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 " " " " " "
 " " " " " "
 Bailer test 20 gal./min. with 84 ft. drawdown after 2 hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 57 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6"
 Depth drilled 301 ft. Depth of completed well 301 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Sandy top soils	0	4
light yellow clay	4	30
whitish (sps) sandstone	30	60
gray sand (med)	60	69
decomposed granite	69	131
gray clay	131	142
whitish sandstone (sps)	142	191
puddle clay	191	203
green clay	203	212
gray clay	212	260
decomposed granite	260	265
gray sand of clay (coarse)	265	301

Work started 9/25 1963 Completed 10/10 1963
 Date well drilling machine moved off of well 10/11 1963

(13) PUMP:

Manufacturer's Name Aermator
 Type: submersible H.P. 3

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Dick Atkins Well Drilling
 (Person, firm or corporation) (Type or print)
 Address P.O. Box 264
DR: 116B - Donald & Leanne
 Drilling Machine Operator's License No. 279

[Signed] Dick Atkins
 (Water Well Contractor)
 Contractor's License No. 260 Date 10/11 1963