

# RECEIVED

CROO  
9510

145/15E-16bd

## STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

JUL - 7 1986

WATER RESOURCES DEPT

SALEM, OREGON

### (1) OWNER:

Name DR. HERB GREY  
Address R.O. BOX 36  
City TROUTDALE State ORE. Zip 97060

### (2) TYPE OF WORK:

New Well  Deepen  Recondition  Abandon

### (3) DRILL METHOD:

Rotary Air  Rotary Mud  Cable  Other

### (4) PROPOSED USE:

Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other

### (5) BORE HOLE CONSTRUCTION:

Depth of Completed Well 250 ft.

Special Standards date of approval \_\_\_\_\_

HOLE			SEAL			Amount sacks or pounds
Diameter	From	To	Material	From	To	
12	0	242	Concrete	0	190	3 1/2 yds

How was seal placed? Method  A  B  C  D  E

Other pumped

Backfill placed from 190 ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_

Gravel placed from 190 ft. to 240 ft. Size of gravel 1/4

### (6) CASING/LINER:

Casing:	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
					<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	8"	+1	250	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Liner: \_\_\_\_\_

### (7) PERFORATIONS/SCREENS:

Perforations Method TORCH  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
235	250	1/8	250	8"		<input checked="" type="checkbox"/>	<input type="checkbox"/>

### (8) WELL TESTS: Minimum testing time is 1 hour

Pump  Bailer  Air  Flowing Artesian 20gpm  
Yield gal/min Pumping level Drill stem at Time

100 65' — 1 hr

Temperature of water 71° Depth Artesian Flow Found 235

Was a water analysis done?  Yes By whom \_\_\_\_\_

Did any strata contain water not suitable for intended use?  Too little

Salty  Muddy  Odor  Colored  Other \_\_\_\_\_

Depth of strata: \_\_\_\_\_

### (9) LOCATION OF WELL by legal description:

County CROOK Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 145 N or S, Range 15E E or W, WM.  
Section 16 N, W 1/4 S, E 1/4  
Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) RT. 3, Box 510

### (10) STATIC WATER LEVEL:

Flowing ft. below land surface. Date 6-1-86  
Artesian pressure 22 lb. per square inch. Date 6-1-86

### (11) WELL LOG:

Material	From	To	WB?	SWL
Top Soil	0	1		
GRAVEL	1	9		
BROWN CLAY	9	42		
Blue - Grey CLAY	42	235		
GRAVEL w/B	235	248	X	
Blue CLAYSTONE	248	253		

Date started 5-28-86 Completed 6-1-86

### (unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed \_\_\_\_\_ Date \_\_\_\_\_

### (bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Clayson Date 6-5-86

Company CLAYSON Well Drilling Co. Job No. \_\_\_\_\_

Tag 38136 CROO  
See C9003  
145/15E-16bd

RECEIVED

JUL - 7 1986

CROO  
9510

STATE OF OREGON  
WATER WELL REPORT  
(as required by ORS 537.765)

WATER RESOURCES DEPT  
Salem, Oregon

(1) OWNER:  
Name Dr. Herb Saez  
Address R.O. Box 36  
City TROUBLE State ORE. Zip 97060

(2) TYPE OF WORK:  
 New Well  Deepen  Recondition  Abandon  
(3) DRILL METHOD:  
 Rotary Air  Rotary Mud  Cable  Other

(4) PROPOSED USE:  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other

(5) BORE HOLE CONSTRUCTION:  
Depth of Completed Well 250 ft.  
Special Standards date of approval \_\_\_\_\_

Diameter	HOLE		Material	SEAL		Amount
	From	To		From	To	
1 1/2	0	250	Concrete	0	170	3 1/2 x 6 1/2

How was seal placed? Method  A  B  C  D  E  
 Other pumped  
Backfill placed from 190 ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
Gravel placed from 170 ft. to 240 ft. Size of gravel 1/4

(6) CASING/LINER:

Casing:	Diameter		Gauge	Steel	Plastic	Welded	Threaded
	From	To					
8"	1	250	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

(7) PERFORATIONS/SCREENS:

Perforations Method TORCH  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
235	250	1/8	200	8"		<input checked="" type="checkbox"/>	<input type="checkbox"/>

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailor  Air  Flowing Artesian 209 pm  
Yield gal/min 100 Pumping level 6.5' Drill stem at \_\_\_\_\_ Time 1 hr

Temperature of water 71° Depth Artesian Flow Found 235  
Was a water analysis done?  Yes By whom \_\_\_\_\_  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
Depth of strata: \_\_\_\_\_

(9) LOCATION OF WELL by legal description:  
County Crook Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
Township 14S N or S, Range 15E E or W, WM.  
Section 16 \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 S1E 1/4  
Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
Street Address of Well (or nearest address) RT 3, Box 310

(10) STATIC WATER LEVEL:  
Flowing \_\_\_\_\_ ft. below land surface. Date 6-1-86  
Artesian pressure 22 lb. per square inch. Date 6-1-86

(11) WELL LOG: Ground elevation \_\_\_\_\_

Material	From	To	WB?	SWL
Top Soil	0	1		
GRAVEL	1	9		
BROWN CLAY	9	42		
Blue - Grey CLAY	42	235		
GRAVEL w/ls	235	248	X	
Blue Claystone	248	253		

Date started 5-28-86 Completed 6-1-86

(unbonded) Water Well Constructor Certification:  
I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed \_\_\_\_\_ Date \_\_\_\_\_

(bonded) Water Well Constructor Certification:  
I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Clyde Claxson Date 6-5-86

Company Claxson Well Drilling Co. Job No. \_\_\_\_\_