NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
AUG 29 1973
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 32S/15W-9 C
State Permit No.

CURR 001026

(1) OWNER:
Name Victor Denn
Address P.O. 752 Port Orford, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 60'-3" ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Torch
Size of perforations 3/16 in. by 6 in.
4 perforations from 41 at 45 ft. to ft.
4 perforations from 48 50 ft. to ft.
4 perforations from 55 ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 2½ gal./min. with total ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 0 sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite Yellowstone
Number of pounds of bentonite per 100 gallons of water 50gal. / 100 lb. lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Curry Driller's well number
¼ SW ¼ Section 9 T. 32s R. 15W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 45 ft.
Static level 44 ft. below land surface. Date 8-25-73
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 60 ft. Depth of completed well 60 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Clay brown	0	10	
Sand & gravel	10	13	
Clay & gravel with boulders	13	40	
Clay & fine gravel tan	40	45	
Gravel	45	48	
Serpentine claystone gray	48	60	

Work started August 24 1973 Completed August 25 1973
Date well drilling machine moved off of well August 27 1973

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Andrew A. Miller Date Aug. 27, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 469

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name George R. Miller & Son Well Drilling
(Person, firm or corporation) (Type or print)
Address Route 1, Box 770 Bandon, Oregon
[Signed] George R. Miller
(Water Well Contractor)
Contractor's License No. 322 Date August 27, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119