NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
DEC 19 1975
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

001032
CURR 1032

State Well No. 32S/15W-9
State Permit No.

(1) OWNER:
Name Bob Sweet
Address Box M Sixes, Oregon 97476

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 33'-5" ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Mills knife
Size of perforations 1/4 in. by 3 in.
4 perforations from at 26'-10" ft. to ft.
4 perforations from at 27'-10" ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 5 gal./min. with total drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 0 sacks
Number of sacks of bentonite used in well seal 3 sacks
Brand name of bentonite Yellowstone
Number of pounds of bentonite per 100 gallons of water 100 lb./50gal. lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Curry Driller's well number
SW ¼ NW ¼ Section 9 T. 32S R. 15W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 23 ft.
Static level 16½ ft. below land surface. Date 12-16-75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 33½ ft. Depth of completed well 33½ ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Clay soil black	0	2	
Clay brown	2	10	
Gravel brown	10	19	
Clay blue	19	23	
Gravel blue	23	28	
Serpentine rock blue	28	33	

Work started 12-15 19 75 Completed 12-16 19 75
Date well drilling machine moved off of well 12-16 19 75

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Andrew W. Miller Date 12-17, 1975.
(Drilling Machine Operator)
Drilling Machine Operator's License No. 469

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name George R. Miller & Son
(Person, firm or corporation) (Type or print)
Address Route 1, Box 770 Bandon, Oregon 97411
[Signed] Andrew W. Miller
(Water Well Contractor)
Contractor's License No. 600 Date 12-17, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119