NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON

(Please type or print)

(Do not write above this line)

(ATER RESOURCES DEPT.

(1) OWNER:	(10) LOCATION OF WELLS
Name Norm Yock Oregon Propagating Co.	County Curry Driller's well number
Address Route 1. Box 52 E	NE 14 NE 14 Section 16 T. 41s R. 13w W.M.
Brookings Oregon 97415	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	Deating and distance from beeded of baselysists
New Well ☐ Deepening A Reconditioning ☐ Abandon ☐	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found $22\frac{1}{2}$ ft.
Retown D Driven D	001.01
Domestic Industrial Municipal Cable Domestic Industrial Municipal Dug Bored Irrigation	Static level 22'-2" ft. below land surface. Date 0-21-/0 Artesian pressure lbs. per square inch. Date
(5) CASING INSTALLED: Threaded	(12) WELL LOG: Diameter of well below casing
of perforator used TORCH	MATERIAL From To SWL
1	This well was originally constructed with
Inknown	a crane many years ago. No information is
periorations from it, to it.	available as to formation or location of
perforations fromft. toft.	perforations. Originally drilled to 32 feet.
perforations from ft. to ft.	OCT LOT GO LOTTE OF SHIPLING TO THE SHIPLING T
(7) SCREENS: Well screen installed? Yes No	Clay and gravel brown 32 34
Manufacturer's Name	Serpentine blue 34 37
Type Model No	8.0
Diam. Slot size Set from ft. to ft.	Three feet of additional casing (8inch)
Diam. Slot size Set from ft. to ft.	installed. Three feet of 6 inch casing with
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	8 inch Oring packer installed
Was a pump test made? ☐ Yes → No If yes, by whom?	#0
Yield: gal./min. with ft. drawdown after hrs.	Well "I
Tierd: gar,/mm. with it. drawdown area.	
" " "	And the second s
Bailer test 40 gal./min. with 5 ft. drawdown after 1 hrs.	
Artesian flow g.p.m.	
Temperature of water 52 Depth artesian flow encountered ft.	Work started 6-21 19 76 Completed 6-21 19 76
CONSTRUCTION:	Date well drilling machine moved off of well 6-21 19 76
Well seal—Material used No additional seal installed Well sealed from land surface to	Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. [Signed] The Land Date 7-10 1976. (Drilling Machine Operator) Drilling Machine Operator's License No. 469
Brand name of bentonite	
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.	Pall Mallow Woll Dwilling
Did any strata contain unusable water? ☐ Yes ☒ No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 1050 Elmira Bandon, Oregon 97411
Method of sealing strata off	La Charles 110 mills
Was well gravel packed? ☑ Yes ☐ No Size of gravel: — 11 2	[Signed] (Water Well Contractor)
Gravel placed from 18. XX	Contractor's License No. 600 Date July 10 , 19.76
TARRETTE MIGUEL INVIII windermark Ekanomin Liv. 60 mg/datamanan Liv.	1