

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

check 125

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

JUL 15 1976

State Well No.

State Permit No. 415/13W-76

WATER RESOURCES DEPT., SALEM, OREGON

ga

(1) OWNER:

Name Norm Yock Oregon Propagating Co.
Address Route 1, Box 52 E
Brookings Oregon 97415

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from 42 ft. to 28'-8" ft. Gage .250
6" Diam. from 38'-9" ft. to 41'-9" ft. Gage .250

(6) PERFORATIONS:

Perforated? Yes No.

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Houston
Type Stainless steel Model No. telescope
Diam. 8 Slot size .025 Set from 27'-6" ft. to 33'-5" ft.
Diam. 8 Slot size .020 Set from 33'-5" ft. to 38'-9" ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Bailer test None gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

CONSTRUCTION:

Well seal—Material used Cement, bentonite, native clay
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 3 X 6 ft. in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite National baroid
Number of pounds of bentonite per 100 gallons of water Dry lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: 1 1/2
Gravel placed from 18 ft. to 39 ft.

(10) LOCATION OF WELL:

County Curry Driller's well number
NE 1/4 NE 1/4 Section 16 T. 41S R. 13W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 25 ft.
Static level 24'-8" ft. below land surface. Date 6-22-76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 0

Depth drilled 41'-9" ft. Depth of completed well 41'-9" ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Well constructed under special standards with excavation to bed rock done with a crane.			
Clay brown	0	19	
Sand & gravel brown	19	38 1/2	
Serpentine blue	38 1/2	42	
Unable to bail test well because of excavation.			
Ten inches of cement grout placed at 18 feet. After grout set, excavation hole was filled with a mixture of 50% bentonite and 50% native clay. Because of size of seal bore to fill, we did not keep a record of the amount of bentonite and cement used as the owner supplied all material. This applies to wells number 1, 7, & 6.			
<u>Well # 1</u>			

Work started 6-21 1976 Completed 6-22 1976
Date well drilling machine moved off of well 6-22 1976

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Andrew H. Friselle Date 7-10, 1976
(Drilling Machine Operator)
Drilling Machine Operator's License No. 469

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Bill Miller Well Drilling
(Person, firm or corporation) (Type or print)
Address 1050 Elmira Bandon, Oregon 97411
[Signed] Andrew H. Friselle
(Water Well Contractor)
Contractor's License No. 600 Date July 10, 1976