NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JAN 8 - 1973 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

(Please type or print)
(Do not write above this line)

001337 CO RR

State Well No. 35S/14W-30a

State Permit No.

(1) OWNER:
Name G. T. Centers
Address 635 Janice Ave - Hayward Calif 94544

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 127'-6" ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☒ Yes ☐ No
Manufacturer's Name Johnson
Type Stainless steel Model No. telescope
Diam. 6 Slot size .010 Set from 126-4" ft. to 132' ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 13 gal./min. with NO ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 4/4 sacks
Number of sacks of bentonite used in well seal 3 sacks
Brand name of bentonite National baroid
Number of pounds of bentonite per 100 gallons of water XX lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Curry Driller's well number
W½ ¼ NE¼ Section 30 T. 35S R. 14W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 120 ft.
Static level 119 ft. below land surface. Date 12-29-72
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing —
Depth drilled 132 ft. Depth of completed well 132 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Sandy soil black	0	2	
Sandy clay brown	2	10	
Sand muddy Fine brown	10	70	
Sand very Fine brown	70	75	
Sand muddy fine brown	75	109	
Sand Course brown	109	132	
Rock Blue-green	132	—	

Work started 12-27 1972 Completed 12-29 1972
Date well drilling machine moved off of well 12-29 1972

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Andrew W. Miller Date 1-5, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 469

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name George R. Miller & Son Drilling
(Person, firm or corporation) (Type or print)
Address Rt. 1, Box 561 Barton Oregon
[Signed] George R. Miller
(Water Well Contractor)
Contractor's License No. 322 Date 1-5, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119