

RECEIVED
AUG 10 1959

CURR 000258

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON

State Well No. 36/14W-21
State Permit No. _____

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

(1) OWNER: Name Gordon Asher, Sr.
Address Gold Beach, Oregon Rt. 1, Box 22

(2) LOCATION OF WELL: County Curry Owner's number, if any _____
Section 21 T. 36 R. 14 W.M.
Bearing and distance from section or subdivision corner
75 ft from S.E. Corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
6" Diam. from 0 ft. to 67 1/2 ft. Gage 12
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used torch and mills knife
SIZE of perforations 1/4 in. by 3 in.
4" perforations from 67 1/2 ft. to 63 1/2 torch
25" perforations from 63 1/2 ft. to 38 mills knife
" perforations from _____ ft. to _____ ft.
" perforations from _____ ft. to _____ ft.
" perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
" Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION: Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal— slab around well
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS: Static level 54 ft. below land surface Date 7/3/59
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: [Signed] Gordon Asher Date _____ 19____
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Don B.
Was a pump test made? Yes No If yes, by whom? _____
Yield: 10 gal./min. with 3 ft. drawdown after 1/2 hrs.
" " " " " "
" " " " " "
Bailer test 15 gal./min. with approx. 5' ft. drawdown after 1/2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 6" OD inches.
Depth drilled 67 1/2 ft. Depth of completed well 67 1/2 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Light brown clay and soil	0	16
Grey serpentine clay	16	22
Hard packed gravel with streaks of clay	22	67 1/2
(Water was found at 64')		

Work started July 1 1959 Completed July 7 1959

(13) PUMP: Manufacturer's Name Burkley
Type: jet H.P. 1

Well Driller's Statement: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Barrington Well Drilling
(Person, firm, or corporation) (Type or print)
Address Rt. 1 Gold Beach, Oregon

Driller's well number _____
[Signed] Donald E. Barrington
(Well Driller)
License No. 201 Date July 7, 1959