NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED APR 25 1972 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 40/14W-11bb

State Permit No.

(1) OWNER:
Name ALBERT CLAYTON
Address FIERRELO ROAD RT. I BOX 249

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 50 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used TORCH
Size of perforations 1/4 x 8 in. by in.
24 perforations from 40 ft. to 50 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 15 gal./min. with 30 ft. drawdown after 1 hrs.
Artesian flow 0 g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used BENTONITE
Well sealed from land surface to 18 FT ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 5/8 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite AQUAGEL
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs 0 Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County CURRY Driller's well number
N.W ¼ N.W ¼ Section 11 T. 40 R. 14W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 35 ft.
Static level 8 ft. below land surface. Date 4-1-72
Artesian pressure 0 lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing NONE
Depth drilled 50 ft. Depth of completed well 50 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
[redacted] SANDSTONE	0	50	
WATER BEARING			
AT 35 FT. BELOW			
LAND SURFACE			

Work started 3-30 1972 Completed 4-1- 1972
Date well drilling machine moved off of well 4-1- 1972

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert Shannon (Drilling Machine Operator) Date 4-22-, 1972
Drilling Machine Operator's License No. 797

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name BROOKINGS WELL DRILLING (Person, firm or corporation) (Type or print)
Address RT. I BOX 61 BROOKINGS
[Signed] Vidi Comerly (Water Well Contractor)
Contractor's License No. 448 Date 4-22, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119