

STATE OF OREGON WATER SUPPLY WELL REPORT

CURR 53248

WELL I.D. LABEL# L 148835 START CARD # 1073560 ORIGINAL LOG #

5/2/2024

(as required by ORS 537.545 & 537.765 and OAR 690-205-0210)

(1) LAND OWNER Owner Well I.D. 2146 First Name ELENORE Last Name FOSKETT Company PISTOL RIVER FRIENDSHIP CLUB Address 24252 CARPENTERVILLE RD. City GOLD BEACH State OR Zip 97444

(2) TYPE OF WORK [X] New Well [] Deepening [] Conversion [] Alteration (complete 2a & 10) [] Abandonment (complete 5a)

(2a) PRE-ALTERATION Dia + From To Gauge Stl Plstc Wld Thrd Casing: Seal:

(3) DRILL METHOD [] Rotary Air [X] Rotary Mud [] Cable [] Auger [] Cable Mud [] Reverse Rotary [] Other

(4) PROPOSED USE [] Domestic [] Irrigation [X] Community [] Industrial/ Commercial [] Livestock [] Dewatering [] Thermal [] Injection [] Other

(5) BORE HOLE CONSTRUCTION Special Standard [X] (Attach copy) Depth of Completed Well 50.25 ft. BORE HOLE Dia From To Material From To Amt sacks/lbs

Table with columns: Dia, From, To, Material, From, To, Amt, sacks/lbs. Row 1: 10, 0, 51, Bentonite Chips, 0, 35, 27, S. Row 2: Calculated, 16.6.

Seal placement method [] A [] B [] C [] D [] E [X] Other: POUR FROM SURFACE Backfill placed from 35 ft. to 51 ft. Material SAND Size 12/20

(5a) ABANDONMENT USING UNHYDRATED BENTONITE Proposed Amount Actual Amount

(6) CASING/LINER Casing Liner Dia + From To Gauge Stl Plstc Wld Thrd Shoe [] Inside [] Outside [] Other Location of shoe(s) Temp casing [X] Yes Dia 10 From + 2 To 18

(7) PERFORATIONS/SCREENS Perforations Method Screens Type Johnson V-Wire Material Stainless Steel Perf/ Casing/ Screen Dia From To Scrn/slot width length slots # of pipe size

(8) WELL TESTS: Minimum testing time is 1 hour [] Pump [] Bailer [X] Air [] Flowing Artesian Yield gal/min Drawdown Drill stem/Pump depth Duration (hr)

Temperature 54 °F Lab analysis [X] Yes By BW&P Water quality concerns? [] Yes (describe below) TDS amount 61 ppm

(9) LOCATION OF WELL (legal description) County CURRY Twp 38.00 S N/S Range 14.00 W E/W WM Sec 29 NW 1/4 of the NW 1/4 Tax Lot 200

(10) STATIC WATER LEVEL Date SWL(psi) + SWL(ft) Existing Well / Pre-Alteration Completed Well 5/1/2024 26

WATER BEARING ZONES Depth water was first found 26.00 SWL Date From To Est Flow SWL(psi) + SWL(ft)

(11) WELL LOG Ground Elevation 55.28 FT Material From To Sand f-m brown 0 2 Sand c-f brown & tan 2 50 Clay brown w/wood 50 51

Construction Begin Date 4/30/2024 Begin Time 12:00 End Date 5/1/2024

(unbonded) Water Well Constructor Certification I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards.


(bonded) Water Well Constructor Certification I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above.

WATER SUPPLY WELL REPORT - Map with location identified must be attached and shall include an approximate scale and north arrow

CURR 53248

5/2/2024

Map of Hole

STATE OF OREGON WELL LOCATION MAP	Oregon Water Resources Department 725 Summer St NE, Salem OR 97301 (503)986-0900	
This map is supplemental to the WATER SUPPLY WELL REPORT		
LOCATION OF WELL	Well Label: 148835	
Latitude: 42.26277034 Datum: WGS84	Printed: May 2, 2024	
Longitude: -124.39642282	DISCLAIMER: This map is intended to represent the approximate location the well. It is not intended to be construed as survey accurate in any manner.	
Township/Range/Section/Quarter-Quarter Section: WM38.00S14.00W29NWNW	Provided by well constructor	
Address of Well: 24252 CARPENTERVILLE RD, PISTOL RIVER		

