

RECEIVED
OCT 3 1961

CURROO.0678

41/13W-5N

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

WATER WELL REPORT
STATE ENGINEER
SALEM, OREGON

State Well No.
State Permit No.

(1) OWNER:

Name Don Hanson
Address R.O. Box 1312
Brookings Oregon

OCT 23 1961 (11) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was pump test made? ☐ Yes ☒ No If yes, by whom?
gal./min. with ft. drawdown after hrs.
" " "

(2) LOCATION OF WELL:

County Curry Owner's number, if any—
SW 1/4 SW 1/4 Section 5 T. 41 S. R. 13 W. W.M.
Bearing and distance from section or subdivision corner
End of Dodge Ave

Bailer test 18 gal./min. with 2 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well 8 inches.

Depth drilled 46 ft. Depth of completed well 46 ft.

Formation: Describe by color, character, size of material and structure, and
show thickness of aquifers and the kind and nature of the material in each
stratum penetrated, with at least one entry for each change of formation.

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☐ Welded ☒

8" Diam. from 0 ft. to 46 ft. Gage 12
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No

Type of perforator used act.
SIZE of perforations 1/8 in. by 4 in.
64 perforations from 3.8 ft. to 46 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed ☐ Yes ☒ No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
I Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 32' ft. below land surface Date 8/9/61
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Don Hanson Date August 10, 1961
(Owner)

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

NAME T. P. Well Drilling
(Person, firm, or corporation) (Type or print)

Address 1590 Oregon St.
Crescent City Cal.

Driller's well number

[Signed] R. L. Tarleton
(Well Driller)

License No. 259 Date 9-2, 1961