RECEIVED
SEP 12 1962
STATE ENGINEER

CURR 760

000760

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 41/13W-9N

State Permit No.

(1) OWNER:
Name A. E. Mikkelsen
Address Rt #1 Box 39-A
Brookings Oregon

(2) LOCATION OF WELL:
County Curry Owner's number, if any—
SW ¼ SW ¼ Section 9 T. 41-S R. 13 W W.M.
Bearing and distance from section or subdivision corner 250' east of SW corner section

(3) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED: Threaded [ ] Welded [X]
8" Diam. from 0 ft. to 26 ft. Gage 12
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? [X] Yes [ ] No
Type of perforator used actylene
SIZE of perforations 1/8 in. by 4 in.
180 perforations from 18 ft. to 26 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? [ ] Yes [X] No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 18 ft. below land surface Date 8/24/62
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] A. E. Mikkelsen (Owner) Date Aug 24, 1962

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 18 gal./min. with 3 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [ ] Yes [X] No

(12) WELL LOG: Diameter of well 8 inches.
Depth drilled 26 ft. Depth of completed well 26 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Black top soil	0	3
Yellow Clay	3	17
Gravel med. to large	17	26

Work started 8/22 1962 Completed 8/24 1962

(13) PUMP:
Manufacturer's Name
Type: H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME T & P Well Drilling (Person, firm, or corporation) (Type or print)
Address 1590 Oregon st Crescent City Cal.
Driller's well number ~~259~~
[Signed] R. J. Towlenton (Well Driller)
License No. 259 Date 8/4, 1962

(USE ADDITIONAL SHEETS IF NECESSARY)