NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

## WATER WELL REPORT

(Please type or print)
(Do not write above the line)

•	(CURR)
	H State Well No. 4/5/13to-15aq
	State Permit No
D,	
A'	TION OF WELL:

Later R	CURCES DEVI.
(1) OWNER: SALLIA.	C(19EdipCATION OF WELL:
Name Pacific Bulb Growers Test Station	County Curry Driller's well number
Address Box AB Brookings Oregon 97415	NE 14 NE 14 Section 15 T.41S R. 13W W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision corner
New Well □ Deepening M Reconditioning M Abandon □	
If abandonment, describe material and procedure in Item 12.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 31'-10" ft.
Cable  Jetted	Static level 31 1-10 ft. below land surface. Date 8-8-78
Dug	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded □ Welded 2	(12) WELL LOG: Diameter of well below casing 0  Depth drilled 46½ ft. Depth of completed well 46½ ft.  Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? Yes   No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used Torch	MATERIAL From To SWL
Size of perforations 1/4 in. by 6 in.	Original
29 perforations from 33 ft. to 45½ ft.	twelve inch perforated casing from 6 to 40'-10
perforations from ft. to ft.	
(7) SCREENS: Well screen installed?   Yes No	Six inch perforated casing installed inside of twelve inch casing and deepened.
Manufacturer's Name	Gravel brown 40 451
Type Model No.	Serpentine blue 45\frac{1}{2} 47\frac{1}{2}
Diam Slot size Set from ft. to ft.	-01 political back
Diam Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? [ Yes No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
" " "	112.
" " "	
Bailer test 20 gal./min. with 3 ft. drawdown after 1 hrs.	
Artesian flow g.p.m.	
perature of water 52 Depth artesian flow encounteredft.	Work started 8-7 19 78 Completed 8-8 1978
(9) CONSTRUCTION:	Date well drilling machine moved off of well 8_8 1978
Well seal—Material used No additional seal installed  Well sealed from land surface to	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision.  Materials used and information reported above are true to my best knowledge and belief.  [Signed] Drilling Machine Operator)  Drilling Machine Operator's License No. 469
A. Comments	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water?   Yes  No	Name Bill Miller Well Drilling (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address Rt. 1, Box 1115 Bandon, Oregon 97411
Method of sealing strata off	Bulletin II.
Was well gravel packed? [] Yes [] No Size of gravel:	[Signed] (Water Well Contractor)
Gravel placed fromft. toft.	Contractor's License No. 600 Date 8-20 , 1978