SS 6/21/82

WATER WELL REPORT STATE OF OREGON

CURR 000806 RECEIVED

AUG3 11982

WATER RESOURCES CEPT. State Permit No. 0 7/56 SALEM, OREGON

<u> </u>	
1) OWNER:	(10) LOCATION OF WELL:
Norm Yock	County Curry Driller's well number
Address Rt. 1, Box 52 E	NE 4 NE 4 Section 16 T. 41s R. 13w W.M.
city Brookings State Ore.	Tax Lot # Lot Blk Subdivision
2) TYPE OF WORK (check):	Address at well location: Same
١	
New Well □ Deepening □ Reconditioning A Abandon □ f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 15 ft.
	Static level 15 ft. below land surface. Date 8-26-82
Rotary Air Driven Domestic Industrial Municipal Domestic Test Well Other D	Artesian pressure lbs. per square inch. Date
Bored Thermal: Withdrawal Reinjection	(12) WELL LOG: Diameter of well below casing0.
(5) CASING INSTALLED: Steel Y Plastic	Depth drilled 26 ft. Depth of completed well 26 ft.
(5) CASING INSTALLED: Steel A Plastic Threaded Welded	Formation: Describe color, texture, grain size and structure of materials; and show
8" Diam. from+2 ft. to .188. ft. Gauge250	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
6" Diam. from 23 '-2"ft. to 26 '-2"ft. Gauge .250	and indicate principal water-bearing strata.
LINER INSTALLED: NO	MATERIAL From To SWL
"Diam. from	State well # 9
(6) PERFORATIONS: Perforated? Yes No	Otate Well 9
Type of perforator used	Clay with bentonite brown 0 10
Size of perforations in. by in.	Concrete 10 14
perforations from ft. to ft.	Gravel coarse brown 14 23
perforations from	Serpentine blue 23 26
perforations from	Serpendine bide 25 20
(7) SCREENS: Well screen installed? Yes □ No	
Manufacturer's Name Johnson	
Type Stainless steel Model No. telescope	
Diam. 8 Slot Size .016 Set from 17'-6" ft. to 23'-2"ft.	
Diam. Slot Size Set from ft. to ft.	
Drawdown is amount water level is lowered	
(8) WELL TESTS: below static level	
a pump test made? Yes No If yes, by whom?	
Preid: gal/min. with ft. drawdown after hrs.	
11 " " "	
Air test gal./min. with drill stem at ft. hrs.	
Bailer test 15 gal/min. with 3 ft. drawdown after 1 hrs.	i e i e e e e e e e e e e e e e e e e e
esian flow g.p.m.	
remperature of water 52 Depth artesian flow encountered ft.	Work started 8-25 19 82 Completed 8-26 19 82
(9) CONSTRUCTION: Special standards: Yes No 🗆	Date well drilling machine moved off of well 8-26 19 82
Well seal—Material used Bentonite Capped with cement	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal12 in.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal8in.	[Signed] (Drilling Machine Operator) Date 8-28, 1982.
Number of sacks of cement used in well seal 9 sacks	Drilling Machine Operator's License No
How was cement grout placed? 300 lb. bentonite used	Diffing Wachine Operator's Dicense 140.
Pumped via XXXXXX tremie pipe	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to
Was pump installed?	the best of my knowledge and belief. Name Bill Miller Well Drilling
Was a drive shoe used? Yes No Plugs Size: location ft.	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water? Yes No	Address Route 1, Box 1115 Bandon, Ore. 97411
Type of Water? depth of strata	10:mat (Haddelle / XVIIII)
Method of sealing strata off	[Signed] (Water Well Contractor)
Was well gravel packed? ☐ Yes No Size of gravel:	Contractor's License No. 600 Date 8-28 , 19.82
Gravel placed from	