STATE OF OREGON

WATER WELL REPORT

(as required by ORS 537.765)

RECEIVED AUG 12 1987 WATER RESOURCES DEPT. SALEM, OREGON

CURR 838 ~~000838~~ 41S/13W-22bd

(1) OWNER: Owner's Well Number:

Name Carol Crockett

Address P. O. Box 2065

City Harbor Oregon State Zip 97415

(2) TYPE OF WORK:

☒ New Well ☐ Deepen ☐ Recondition ☐ Abandon

(3) DRILL METHOD:

☐ Rotary Air ☐ Rotary Mud ☐ Cable ☒ Other

Hand Dug

(4) PROPOSED USE:

☐ Domestic ☐ Community ☐ Industrial ☒ Irrigation

☐ Thermal ☐ Injection ☐ Other

(5) BORE HOLE CONSTRUCTION:

Depth of Completed Well 28 ft.

Special Standards date of approval yes

HOLE Diameter	From	To	SEAL Material	From	To	Amount sacks or pounds
54	0	16½	concrete	5 sx mix		
				0	16½	2½ cu yds

How was seal placed? Method ☐ A ☐ B ☐ C ☐ D ☐ E

☒ Other redimix truck

Backfill placed from ft. to ft. Material none

Gravel placed from ft. to ft. Size of gravel none

(6) CASING/LINER: pre-cast concrete*

	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing:	42"	+1	28	2"	☐	☐	☐	☐
Liner:	none				☐	☐	☐	☐

Final location of shoe(s) none

(7) PERFORATIONS/SCREENS:

☐ Perforations Method none

☐ Screens Type Material

From	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
						☐	☐

(8) WELL TESTS: Minimum testing time is 1 hour

☒ Pump ☐ Bailer ☐ Air ☐ Flowing Artesian

Yield gal/min	Pumping level	Drill stem at	Time ½ hr
10	18	-	* 1 hr
12	21	-	* 1 hr

Temperature of water 53 Depth Artesian Flow Found

Was a water analysis done? ☐ Yes By whom

Did any strata contain water not suitable for intended use? ☐ Too little no

☐ Salty ☐ Muddy ☐ Odor ☐ Colored ☐ Other

Depth of strata:

(9) LOCATION OF WELL by legal description:

County Curry Latitude ' " Longitude ' "

Township 41 S N or S, Range 13 WWM E or W, WM.

Section 22B ¼ SE ¼ NW ¼

Tax Lot 101 Lot Block Subdivision

Street Address of Well (or nearest address) Oceanview Drive

(10) STATIC WATER LEVEL:

16½ ft. below land surface. Date 6/29/87

Artesian pressure lb. per square inch. Date

(11) WELL LOG: Ground elevation

Material	From	To	WB?	SWL
Topsoil, black	0	2½		
clay, brown	2½	6		
samd & gravel & clay	6	9		
sand & gravel, firm	9	13½		
sand & gravel, loose	13½	16½	x	16½
gravel, med. loose	16½	18	x	x
gravel & large rocks	18	21	x	16½
clay, brown, firm	21	22		
clay & rock, drk grey (serpintine)	22	28		

Date started 6/9/87 Completed 7/12/87

(unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Date

(bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Fw H Moyle Date Aug 10, 87

Company Greenacres Hand Dug Wells Co. Job No. 87-112

9809C 10/85