

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

000954
CURR 9.6.74

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

RECEIVED

SEP 17 1974

State Well No.

31S/15W-22bd

STATE ENGINEER
SALEM, OREGON

State Permit No.

(1) OWNER:

Name Ralph & Marie Page
Address Star Rt Box 213
Langlois, Oregon 97450

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

precast concrete
4.2" Diam. from 0 ft. to 40 ft. Gage 2"
" Diam. from " ft. to " ft. Gage "
" Diam. from " ft. to " ft. Gage "

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Contractor

Yield: 30 gal./min. with 2 ft. drawdown after 3 hrs.

Baller test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m.

Temperature of water 52 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

truck order concrete

Well seal—Material used _____

Well sealed from land surface to 18 ft.

Diameter of well bore to bottom of seal 54 in.

Diameter of well bore below seal 46 in.

Number of sacks of cement used in well seal redimix sacks

Number of sacks of bentonite used in well seal _____ sacks

Brand name of bentonite _____

Number of pounds of bentonite per 100 gallons _____

of water _____ lbs./100 gals.

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Curry Driller's well number 471-8
S E 1/4 N W 1/4 Section 22 T. 31S R. 15 W W.M.
Bearing and distance from section or subdivision corner 460' W
& 180' N of subdivisions SE corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 30 ft.
Static level 30 ft. below land surface. Date 8/22/74
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 40 ft. Depth of completed well 40 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
tppsoil	0	2	
clay, red & yellow	2	8	
sandstone, med, brown	8	10	
sand, brown, med	10	18	
sandstone, brown	18	19	
sand, grey	19	28	
sandstone, brown	28	29	
sand & sml gravel mix	29	35	30
small gravel	35	40	30

Work started 8/15 19 74 Completed 8/22 19 74

Date well drilling machine moved off of well 8/22/74 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] _____ Date _____, 19 _____

(Drilling Machine Operator)

Drilling Machine Operator's License No. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Greenacres Tile Yard

(Person, firm or corporation)

(Type or print)

Address Rt 1 Box 580, Coos Bay

[Signed] R W Mc Bride

(Water Well Contractor)

Contractor's License No. 471 Date Setp 13, 19 74