NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT.
SALEM, OREGON 97310
within 30 days from the date
of well completion.

State Permit No. G-8566

	**		
(1) OWNER: \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	61997LOCATION OF WELL:		
Name Harold Dunegan	NCounty Deschutes Driller's well no		
Address Rt. 1 Box 245	NW 14 SE 14 Section 1. T. 14S	R. 11E	W.M.
Terrebonne, Ore. 97760	Bearing and distance from section or subdivision	on corner	
(2) TYPE OF WORK (check):			
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 345 ft.		
Rotary Driven Domestic Industrial Municipal	Static level 342 ft. below land surface. Date 8-14-78		
Cable	Artesian pressure lbs. per square inch. Date		
	Tit testan pressure		
CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well below casing 12"		
16 " Diam. from 2 ft. to -18 ft. Gage • 250	Depth drilled 396 ft. Depth of completed well 396 ft.		
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials;		
" Diam. from ft. to ft. Gage	and show thickness and nature of each stratus	m and aquifer pen	netrated,
PERFORATIONS: Perforated? Yes KNo.	with at least one entry for each change of format position of Static Water Level and indicate prin		
	MATERIAL	From To	SWL
		0 3	
Size of perforations in. by in.	brown sandy soil	3 10	
perforations from	brown sandstone	10 18	
perforations from	grey hard rock brown hard rock	18 37	
perforations from tt. to ft.	brown broken hard rock	37 89	
(7) SCREENS: Well screen installed? Yes 7 No	brown sandstone conglomerate	89 130	
Manufacturer's Name	grey hard broken rock	130 260	
Type Model No	brown hard broken rock	260 346	342
Diam. Slot size Set from ft. to ft.	black broken rock WB	34 6 39 1	
Diam. Slot size Set from ft. to ft.	brown hard rock	391 396	
	DIOWII HATO TOCK		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? ☐ Yes ∑ No If yes, by whom?			
Yield: gal./min. with ft. drawdown after hrs.			
" " "			
n " " " "			
Bailer test / gal./min. with NO ft. drawdown after \(\perp\) hrs.		 	
Artesian flow g.p.m.			
perature of water Depth artesian flow encountered ft.	Work started 7-13 1978 Complete		19 78
(9) CONSTRUCTION:	Date well drilling machine moved off of well	8-16	19 78
gement	Drilling Machine Operator's Certification:		
_18	This well was constructed under my	direct superv	ision.
Well sealed from land surface toft. Diameter of well bore to bottom of sealin.	Materials used and information reported best knowledge and belief.	above are true	to my
12		Date 8-17	10 78
Diameter of well bore below seal in. Number of sacks of cement used in well seal 12 sacks	(Drilling Machine Operator)	Date	19
How was cement grout placed? gravity flow	Drilling Machine Operator's License No.	678	
	Water Well Contractor's Certification:		
	This well was drilled under my jurisdi		port is
Was a drive shoe used? ☐ Yes KNo Plugs Size: location ft.	true to the best of my knowledge and belief. Name Crawford Well Drilling, Inc.		
Did any strata contain unusable water? 🗌 Yes 🙇 No	Name Crawlord WELL Drilling, (Person, firm or corporation)	(Type or print	:)
Type of water? depth of strata	Address 1245 NW Lower Bridge T	errebenne)re
Method of sealing strata off	1 0	~	
₹	[Signed] (Water Well Contr	actor)	
	Contractor's License No570 Date	8-17	19 78
Gravel placed from . ft. to ft.	COLMECTOR DESCRIBE THE Date	·····	,