NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

DESC 2010

RECEIVED
JUL 14 1975
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 14S/11E-28
State Permit No. G-11566

(1) OWNER:
Name Charles & Ruth Lynch
Address St Rt Goodrich Loop, Redmond 97756

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
8" Diam. from +1 ft. to -18 ft. Gage .250
6" Diam. from 0 ft. to 560 ft. Gage .188
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used torch
Size of perforations 1/8 in. by 12 in.
99 perforations from 520 ft. to 560 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 7 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 49 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 7 sacks
Number of sacks of bentonite used in well seal 0 sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Deschutes Driller's well number
NE ¼ NW ¼ Section 28 T. 14S R. 11E W.M.
Bearing and distance from section or subdivision corner
930' S and 204' W of N¼ corner Sec 28

(11) WATER LEVEL: Completed well.
Depth at which water was first found 530 ft.
Static level 512 ft. below land surface. Date 7/7/75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 0
Depth drilled 569 ft. Depth of completed well 560 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
brown sandy soil	0	2	
hard gray rock	2	15	
brown clay congl	15	32	
hard black rock	32	95	
redish brn sandstone congl	95	110	
tan sandstone congl	110	150	
brown sandstone congl	150	230	
med hd black rock	230	255	
brown sandstone congl	255	286	
med hd broken brn rock	286	308	
brown sandstone	308	390	
black sandstone congl	390	425	
blk brk rock med hd (WB)	425	565	512

Work started 6/19 1975 Completed 7/7 1975
Date well drilling machine moved off of well 7/7 1975

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Dale Paul Dow (Drilling Machine Operator) Date 7/10, 1975
Drilling Machine Operator's License No. 934

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Crawford Well Drilling (Person, firm or corporation) (Type or print)
Address 3626 N.W. Coyner Redmond, Oregon
[Signed] John V. Johnson (Water Well Contractor)
Contractor's License No. 395 Date 7/10, 1975

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119