

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

Do not write above this line)

DESC

2266

State Well No.

14/13-10

State Permit No.

(1) OWNER:

Name JIM SHOCKER
Address REDMOND ONE - 97750

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

☐ Driven ☐
☒ Jetted ☐
☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒

6.5" Diam. from 0 ft. to 20 ft. Gage 150

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 298 ft. below land surface Date 8-20-69

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 15 gal./min. with 10 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water 54 Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used CEMENT

Depth of seal 20 ft.

Diameter of well bore to bottom of seal 5 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☐ Yes ☒ No

Did any strata contain unusable water? ☐ Yes ☐ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County DESC Driller's well number

1/4 1/4 Section 10 T. 14 S. R. 13 E W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 335 ft. Depth of completed well 335 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
OVERBURDEN	0	3	
SOFT LAVA	3	180	
RED CLAYERS	180	189	
BROWN SANDSTONE	189	298	
WATER BEARING SAND	298	335	298

Work started 8-5 1969 Completed 8-20 1969

Date well drilling machine moved off of well 8-20 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Joe Lannon Date 8-25, 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 116

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Hurst Well Drilling
(Person, firm or corporation) (Type or print)

Address 836 S 12th Redmond

[Signed] Paul P. Tackitt
(Water Well Contractor)

Contractor's License No. 318 Date 8-24, 1969