NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be

filed with the

WATER WELL REPORTE CEIVED

145/13E-21

STATE ENGINEER, SALEM, OREGON 9710 E within 30 days from the date of well completion.

DESC 2457

STATE OF OREGON

JAN201976 tate Well No.

(Please type or print) WATER RESOURCES, DEPTmit No. 6-6973
(Do not write above this line) SALEM, OREGON

(1) OWNER:	(10) LOCATION OF WELL:
Name Ed Savage	County Deschutes Driller's well number
Address 1800 SW Newell Terrebonne, Ore	NW 1/4 SW 1/4 Section 21 T. 14S R. 13F. W.M.
And the state of t	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well □ Deepening □ Reconditioning □ Abandon □	105'E 4186'S LAW Corner Lot 6
If abandonment, describe material and procedure in Item 12.	7/
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 139 ft
Cable	Static level 123 ft. below land surface. Date 1/7/76
Dug Bored Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded To Welded To	
CASING INSTALLED: Threaded Welded Threaded Welded Threaded T	(12) WELL LOG: Diameter of well below casingO
6 "Diam. from -1 ft. to 165 ft. Gage 188	Depth drilled 165 ft. Depth of completed well 165 ft.
"Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size and structure of materials;
Diani. Holi	and show thickness and nature of each stratum and aquifer penetrated
PERFORATIONS: Perforated? If Yes I No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used torch	
Size of perforations 1/8 in. by 12 in.	
88 perforations from 125 ft. to 165 ft.	brn soil 0 1
po-202010110 110111	brn clay congl 1 3
perforations fromft. toft.	red cinders med to fine 3 51
perforations from ft. to ft.	brn sandstone med to fine 51 92
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	hd gray rock 92 106
Manufacturer's Name	brn sandstone & bldrs 106 139
Type Model No.	brn sand & gravel (WB) 139 162
Diam Slot size Set from ft. to ft.	brkn brn rock 162 165 123
Diam. Slot size ft. to ft.	
(0) TITEL T INDICATE Drawdown is a second of the control of the co	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes ☒ No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	
" " " " " " " " " " " " " " " " " " " "	
The state of the s	
Bailer test 18 gal./min. with 0 ft. drawdown after 1 hrs.	
Artesian flow g.p.m.	
perature of water 62 Depth artesian flow encountered ft.	Work started 12/30 19.75 Completed 1/7 1976
(9) CONSTRUCTION:	Date well drilling machine moved off of well 1/7 1976
Well seal-Material used cement	Drilling Machine Operator's Certification:
Well sealed from land surface to59ft	This well was constructed under my direct supervision
Diameter of well bore to bottom of seal12in.	Materials used and information reported above are true to my
Diameter of well bore below seal	best knowledge and belief.
Number of sacks of cement used in well seal23sacks	[Signed] 1 Date 1 / 9, 1976
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No
Brand name of bentonite	
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this report is
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.	true to the best of my knowledge and belief.
Did any strata contain unusable water? Yes No	Name Crawford Well Drilling (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 3626 NW Coyner Redmond, Ore
Method of sealing strata off	
Was well gravel packed? ☐ Yes ☒ No Size of gravel:	[Signed] John Jahusand
Gravel placed from ft. to ft.	(Water Well Contractor)
It. W It.	Contractor's License No. 5 75 Date 1/ 0 1976