NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

DESC 2497
RECEIVED AUG 26 1969
STATE ENGINEER SALEM, OREGON

# WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 14/13-23
State Permit No.

## (1) OWNER:
Name GEORGE ADAMS
Address REDMOND ORE

## (2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

## (3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

## (4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

## (5) CASING INSTALLED:
Threaded ☐ Welded ☒
8 5/8" Diam. from 0 ft. to 18 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

## (6) PERFORATIONS:
Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

## (7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

## WATER LEVEL: Completed well.
Static level 120 ft. below land surface Date 8-20-69
Artesian pressure lbs. per square inch Date

## (9) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 20 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water 53 Was a chemical analysis made? ☐ Yes ☒ No

## (10) CONSTRUCTION:
Well seal—Material used CEMENT - BENT.
Depth of seal 18 ft.
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

## (11) LOCATION OF WELL:
County DESC Driller's well number
¼ ¼ Section 23 T. 14 S R. 13 E W.M.
Bearing and distance from section or subdivision corner

## (12) WELL LOG:
Diameter of well below casing 8
Depth drilled 152 ft. Depth of completed well 152 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

| MATERIAL | From | To | SWL |
|---|---|---|---|
| OVER BURDEN | 0 | 5 | |
| SOFT LAVA | 5 | 120 | |
| WATER BEARING SAND | 120 | 152 | 120 |

Work started 8-2 1969 Completed 8-20 1969
Date well drilling machine moved off of well 8-20 1969

**Drilling Machine Operator's Certification:**
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Cecil E. Tackitt (Drilling Machine Operator) Date 8-20, 1969
Drilling Machine Operator's License No. 139

**Water Well Contractor's Certification:**
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Horst Well Drilling (Person, firm or corporation) (Type or print)
Address 836 S 12th st Redmond
[Signed] Cecil E. Tackitt (Water Well Contractor)
Contractor's License No. 318 Date 8-20, 1969

(USE ADDITIONAL SHEETS IF NECESSARY)