NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

DESC 2752

WATER WELL REPORT

STATE OF OREGON

(Please type or print) (Do not write above this line)

Revised

State Well No. 14S/13E-36

State Permit No.

DESC 2752

(1) OWNER:

Name Jay Myers

Address 6175 S.W. McVey Ave.
Redmond, Oregon 97701

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☐

6 " Diam. from +1 ft. to 19 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom?

Yield: 30 gal./min. with 0 ft. drawdown after 3 hrs.

" " " "

" " " "

Bailer test 15 gal./min. with 0 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water 50* Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 19 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 8 in.

Number of sacks of cement used in well seal 7 sacks

How was cement grout placed? pour down

Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Deschutes Driller's well number

¼ ¼ Section 36 T. 14S R. 13E W.M.

Bearing and distance from section or subdivision corner

Blk. 15, Lot 3, Lake Park Estates

(11) WATER LEVEL: Completed well.

Depth at which water was first found 250 ft.

Static level 240 ft. below land surface. Date 4-20-79

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 280 ft. Depth of completed well 280 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sandy Top Soil	0	15	
Hard Grey Lava	15	98	
Brown Sandstone	98	250	240
Water-Bearing Sandstone	250	280	

RECEIVED
DEC 6 1979
WATER RESOURCES DEPT
SALEM, OREGON

Work started 4-20 1978 Completed 4-20 1978

Date well drilling machine moved off of well 4-20 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] William D. Aiken (Drilling Machine Operator) Date 4-20, 1978

Drilling Machine Operator's License No. 803

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Orvail Buckner (Person, firm or corporation) (Type or print)

Address 1686 N.E. Negus Way, Redmond, Ore. 97756

[Signed] Orvail Buckner (Water Well Contractor)

Contractor's License No. 608 Date 9-25, 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119

DESC 2752

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date of well completion.

DESC 2752

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED MAY 11 1978

14S 13E 36 B
State Well No. 15S/14E-36
State Permit No.

(1) OWNER:
Name JAY MEYERS
Address 6175 S.W. McVEY AVE, REDMOND, ORE. 97756

(2) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):
Domestic [X] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:
Threaded [] Welded []
6 " Diam. from +1 ft. to 19 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 15 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 50° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 7 sacks
How was cement grout placed? pipe down
Was a drive shoe used? [] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County DESCHUTES Driller's well number
¼ ¼ Section 36 T. 15S R. 14E. W.M.
Bearing and distance from section or subdivision corner
BLK. 15 - LOT 3, LAKE PARK ESTATES

(11) WATER LEVEL: Completed well.
Depth at which water was first found 250 ft.
Static level 240 ft. below land surface. Date 4-20-78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 8"
Depth drilled 280 ft. Depth of completed well 280 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SANDY TOP SOIL	0	15	
HARD GRY LAVA	15	98	
BROWN SAND STONE	98	250	240
WATER BEARING SANDSTONE	250	280	

Work started 4-20 1978 Completed 4-20 1978
Date well drilling machine moved off of well 4-20 1978

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] William D. Allen (Drilling Machine Operator) Date 4-20, 1978
Drilling Machine Operator's License No. 803

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name ORVAIL BUCKNER (Person, firm or corporation) (Type or print)
Address 1186 N.E. NEGUS WAY, REDMOND ORE. 97756
[Signed] Orvail Buckner by partner-Jr. attorney (Water Well Contractor)
Contractor's License No. 608 Date 4-25, 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119