

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report are to be filed with the

RECEIVED
WATER WELL REPORT
 STATE OF OREGON
 (Please type or print)
 STATE ENGINEER
 SALEM, OREGON

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date of well completion.

MAY 7 1975
 State Well No. 155/10E-3.66
 State Permit No. _____

(1) OWNER:

Name Richard May (Fred Wells-builder)
 Address Scottsdale, Arizona

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(10) LOCATION OF WELL:

County Deschutes Driller's well number _____
NW 1/4 NW 1/4 Section 3 T. 15S R. 10E W.M.
 Bearing and distance from section or subdivision corner 1125' East & 305' South of NW corner Sec 3
Tract 1 block 1 Barclay Place

(11) WATER LEVEL: Completed well.

Depth at which water was first found 85 ft.
 Static level 76 ft. below land surface. Date 4/23/75
 Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 0
 Depth drilled 102 ft. Depth of completed well 102 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
brown sandy soil	0	2	
redish brn sandstone	2	35	
brown sandstone	35	85	
red & blk cinders (water)	85	102	76

CASING INSTALLED:

Threaded Welded
8" Diam. from + 1 ft. to - 20 ft. Gage .250
6" Diam. from 0 ft. to 100 ft. Gage .188
 _____" Diam. from _____ ft. to _____ ft. Gage _____

PERFORATIONS:

Perforated? Yes No
 Type of perforator used torch
 Size of perforations 1/8 in. by 12 in.
90 perforations from 70 ft. to 100 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 " " " " " "
 " " " " " "
 Baller test 20 gal./min. with 0 ft. drawdown after 1 hrs.
 Artesian flow _____ g.p.m.
 Temperature of water 50° Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used cement
 Well sealed from land surface to 20 ft.
 Diameter of well bore to bottom of seal 14 in.
 Diameter of well bore below seal 8 in.
 Number of sacks of cement used in well seal 9 sacks
 Number of sacks of bentonite used in well seal 0 sacks
 Brand name of bentonite _____
 Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
 Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

Work started 4/18 1975 Completed 4/23 1975
 Date well drilling machine moved off of well 4/23 1975

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
 [Signed] Dale Paul Drew Date 4/30, 1975.
 (Drilling Machine Operator)
 Drilling Machine Operator's License No. 934

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 Name Crawford Well Drilling
 (Person, firm or corporation) (Type or print)
 Address 3626 N.W. Coyner Redmond, Oregon
 [Signed] John Johnson
 (Water Well Contractor)
 Contractor's License No. 595 Date 4/30, 1975