NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
NOV 23 1977
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print) (Do not write above this line)

DESC 3046

State Well No. 15S/10E-10dd

State Permit No.

(1) OWNER:
Name Lester Curtis
Address P. O. Box 527 Sisters, ore.

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [X] Driven [ ]
Cable [ ] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(5) CASING INSTALLED:
Threaded [ ] Welded [X]
8 " Diam. from 2 ft. to -19 ft. Gage .250
6 " Diam. from 1 ft. to -65 ft. Gage .188
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? [X] Yes [ ] No
Type of perforator used factory
Size of perforations 1/4 in. by 3 in.
160 perforations from -45 ft. to -65 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 10 gal./min. with 6 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 8 sacks
How was cement grout placed? gravity flow
Was a drive shoe used? [ ] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [X] Yes [ ] No untested
Type of water? surface depth of strata 2'
Method of sealing strata off cement
Was well gravel packed? [ ] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Deschutes Driller's well number
NE 1/4 NW 1/4 Section 10 T. 15S R. 10 E W.M.
Bearing and distance from section or subdivision corner
2157' E and 946' S of N.W. corner of section 10

(11) WATER LEVEL: Completed well.
Depth at which water was first found 10 ft.
Static level 23 ft. below land surface. Date 11-1-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 0
Depth drilled 65 ft. Depth of completed well 65 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
brown sandy soil	0	2	
brown conglomerate & large boulders	2	9	
black coarse gravel- water	9	12	
brown coarse conglomerate	12	23	23
black coarse gravel- WB	23	65	

Work started 11-1 19 77 Completed 11-3 19 77
Date well drilling machine moved off of well 11-3 19 77

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Dale Drew (Drilling Machine Operator) Date 11-15, 19 77
Drilling Machine Operator's License No. 934

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Crawford Well Drilling (Person, firm or corporation) (Type or print)
Address 1245 NW Lower Bridge Terrebonne, Ore.
[Signed] Larry K. Crawford (Water Well Contractor)
Contractor's License No. 570 Date 11-15, 1977

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119