NOTICE TO WATER WELL CONTRACTOR
The original and first coov
of this report are to be
filed with the WATER WELL REPORTUL 1 11973 STATE OF OREGON TE ENGINE Pell No. 155/10 E-2 STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion. (Please type or printSALEM OREGON Permit No. (Do not write above this line)

(1) OWNER:	(10) LOCATION OF WELL:
Name MR. & MRS. GARY RODGERS	County Deschara Driller's well number
Address & D. DOX BENJ OLEMAN	14 56 14 Section 24 T. 15 R. 10 EW.M.
9/10	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	
New Well       Deepening □ Reconditioning □ Abandon □	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found ft.
Rotary Driven Domestic M Industrial Municipal	
Cable 12 Jetted   Dug   Bored   Irrigation   Test Well   Other	Static level 250 ft. below land surface. Date 5/18/23
Date Charles Charles and Charles and Charles C	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded   Welded	(12) WELL LOG: Diameter of well below casing
8 "Diam. from + 18" X to 110 ft. Gage 250	Depth drilled 290 ft. Depth of completed well 290 ft.
ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,
PERFORATIONS: Perforated? W Yes I No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used COTTIGG TORGH	MATERIAL From To SWL
Size of perforations in. by 8 in.	BOLD & CONG 0 90
96 perforations from 26.6 ft. to 290 ft.	BROKEN BASALT 90 160
perforations fromft. toft.	BROKEN BASALT 90 160
perforations from ft. to ft.	SAND STONE RED 160 245
(7) SCREENS: Well screen installed?   Yes  You	JAND 37 671 L 14-0 7 00 147
Manufacturer's Name	CONE 1 BOLD 245- 265
Type Model No.	,
Diam. Slot size Set from ft. to ft.	WATER BEARING SAND 165 290
Diam. Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is	
lowered below static level	
Was a pump test made? Yes You If yes, by whom?	
Yield: 30 gal./min. with / 0 ft. drawdown after 3 hrs.	
" " "	
" " " "	
Bailer test /2 gal./min. with /6 ft. drawdown after / hrs.	
Artesian flow g.p.m.	
perature of water Depth artesian flow encountered ft.	Work started 4//0/73 19 Completed 5/20/73 19
	Date well drilling machine moved off of well 5/20/22 19
(9) CONSTRUCTION:	
Well seal-Material used CEMENT & DAILL CUTTINES	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision.
Well sealed from land surface toft.	Materials used and information reported above are true to my
Diameter of well bore to bottom of sealin.	best knowledge and belief.
Diameter of well bore below seal in.	[Signed] 37 / Stug Date 5/22, 1973
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No
Number of sacks of bentonite used in well seal sacks	Drining Machine Operator's Literise No
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is
of water	true to the hest of my knowledge and belief.
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.  Did any strata contain unusable water? ☐ Yes ☒ No	Name // Wy 1 Sou NEW UNILLING Co.
	Address P. (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address Dox 1161 DEBO ORE
Method of sealing strata off	[Signed] Mohr H Mclay
Was well gravel packed? ☐ Yes ☑ No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. 480 Date 5/22 , 19.73
(USE ADDITIONAL SHEETS IF NECESSARY)	