NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

DESC 35/2

WATER WELL REPORT
STATE OF OREGON
(Please type or print) (Do not write above this line)

RECEIVED
MAR 15 1978
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 15S/12E-11bd
State Permit No.

(1) OWNER:
Name John Weis
Address Rt 1 Box 320
Gervais, Oregon 97026

(2) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):
Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

CASING INSTALLED:
Threaded [] Welded [X]
12 — 12" Diam. from 0 ft. to 342 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? [X] Yes [] No
Type of perforator used Torch Cut
Size of perforations 3/16 in. by 6 in.
#700 perforations from 222 ft. to 342 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 100 gal./min. with 0 ft. drawdown after hrs.
air
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used CEMENT
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 15 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 16 sacks
How was cement grout placed?
Hand mixed-hand placed
Was a drive shoe used? [] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Deschutes Driller's well number 15278G
SE ¼ NW¼ Section 11 T. 15S R. 12E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 210 ft.
Static level 210 ft. below land surface. Date 2/27/78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 12"
Depth drilled 342 ft. Depth of completed well 342 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	2	
Brown Sandy Clay and Boulder	2	5	
Brown Sand Stone (soft)	5	36	
Blue Factured Sand Rock	36	40	
Redish Brown Sand Rock	40	52	
Gray Basalt	52	93	
Redish Brown Sand Stone	93	98	
Red Sand Stone(soft)	98	115	
Brown & Black Sand Stone	115	342	

Work started 2/9 19 78 Completed 2/27 19 78
Date well drilling machine moved off of well 2/27 1978

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] George M. Simpson (Drilling Machine Operator) Date 3/6, 1978
Drilling Machine Operator's License No. 1072

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Schoen Electric, Inc. (Person, firm or corporation) (Type or print)
Address 626 West Queen Albany, Ore 97321
[Signed] Samuel E. Schoen (Water Well Contractor)
Contractor's License No. 513 Date 2/27, 19 78

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119