
WATER WELL REPORT STATE OF OREGON



RECEIVED 155/12E-14db

WATER RESUMEES DEPT

GAL SETCON

(1) OWNER:	(10) LOCATION OF WELL:	
Name OREGON STATE PARKS DIVISION	County DESCHUTES Driller's well number 82 - 1	
Address P.O. BOX 5309	NW 4 SE 4 Section 14 T. 15 S R.12 E	W.M.
City BEND OREGON State 97708	Tax Lot # Lot Blk Subdivision	
(2) TYPE OF WORK (check):	Address at well location: CLINE FALLS STATE PARI	Σ
New Well Deepening □ Reconditioning □ Abandon □		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
	Depth at which water was first found 32 ft.	
(3) TYPE OF WELL: STATE PARK USE (check):	Static level 14 ft. below land surface. Date 3 - 17 - 8	
Rotary Air Driven Domestic Industrial Municipal Rotary Mud Dug DI Irrigation Test Well Dother IX	Artesian pressure lbs. per square inch. Date	
Rotary Mud	(12) WELL LOG: Diameter of well below cases	
(5) CASING INSTALLED: Steel Z Plastic	Depth drilled 48 ft. Depth of completed well 40	0 ft.
Threaded 🗆 Welded 🍇	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry	
6" Diam. from + 1 ft. to 4.0 ft. Gauge 25.0	for each change of formation. Report each change in position of Static Wa	
"Diam. from ft. to ft. Gauge	and indicate principal water-bearing strata.	-
LINER INSTALLED:	MATERIAL From To	SWL
	BROWN SANDY SOIL 0 3	
	GRAY BROKEN ROCK 3 20	
(6) PERFORATIONS: Perforated? □ Yes X No	BROWN CINDERS 20 32	
Type of perforation used Size of perforations in. by in.	SAND 32 43	14
	SAND. BROWN CLAY & 43	
perforations from	COBBLES 48	14
perforations from		
perforations from ft. to ft.		
(7) SCREENS: Well screen installed? ▼ Yes □ No		
Manufacturer's Name JOHNSON'S		
Type TELESCOPING Model No.		
Diam	:	
Diam. Slot Size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? XYes \(\square\) No If yes, by whom? CONTRACTOR		
Id: 30 gal/min. with 13 ft. drawdown after 6 hrs.		
Air test gal/min. with drill stem at ft. hrs.		
Air test gal./min. with drill stem at ft. hrs. Bailer test gal./min. with ft. drawdown after hrs.		
hperature of water 5 3 Depth artesian flow encountered ft.		
· · · · · · · · · · · · · · · · · · ·	Work started 3-3 19 82 Completed 3-24	812
(9) CONSTRUCTION: Special standards: Yes \(\text{No } \text{X} \)	Date well drilling machine moved off of well 3-25	812
Well seal—Material used	Drilling Machine Operator's Certification:	
Well sealed from land surface to	This well was constructed under my direct supervision. Mater and information reported above are true to my best knowledge an	
Diameter of well bore to bottom of seal		-
Diameter of well bore below sealb	[Signed] Thomas A. Aland Date 3.–28., 19.82	
Number of sacks of cement used in well seal	Drilling Machine Operator's License No9.7.8.	
How was cement grout placed? PRESSURE GROUTED FROM BOTTOM	Water Well Contractor's Certification:	
	This well was drilled under my jurisdiction and this report	ia truo to
Was pump installed?N.O	the best of my knowledge and belief.	
Was a drive shoe used? X Yes \(\text{No} \) No \(\text{Plugs} \) Size: location \(Name FLORES DRILLING & PUMP COMPANY	
Did any strata contain unusable water? \square Yes \square No	Address 12143 RIVER RD. N.E., GERVAIS 97026	
Type of Water? depth of strata	ا م	
Method of sealing strata off	[Signed] Thomas A Three (Water Well Contractor)	
Was well gravel packed? ☐ Yes ☐ No Size of gravel:	(Water Well Contractor) Contractor's License No	10 8
Gravel placed from ft. to ft.	COMMUNICATION OF THE PROPERTY	., 137
NOTICE TO WATER WELL CONTRACTOR	WATER RESOURCES DEPARTMENT, SF	*12658-690