

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

MAR 18 1969

STATE OF OREGON

(Please type or print)

(Do not write above this line)

SALEM, OREGON

DESC 3773

WATER WELL REPORT

State Well No. 15/13-6 abc

State Permit No. G-5697

G-6845
G-4862

(1) OWNER:

Name CHARLES RHODES

Address REDMOND ORE.

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒

12" Diam. from 0 ft. to 207 ft. Gage 250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☒ Yes ☐ No.

Type of perforator used factory

Size of perforations 1/4 in. by 2 1/2 in.
2800 perforations from 107 ft. to 207 ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 95 ft. below land surface Date

Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom?

Field: 50 gal./min. with 0 ft. drawdown after 7 hrs.

" " " "

" " " "

Ball test 50 gal./min. with 0 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water 51° Was a chemical analysis made? ☐ Yes ☒ No

(10) CONSTRUCTION:

Well seal—Material used Benoite

Depth of seal 20 feet ft.

Diameter of well bore to bottom of seal 14 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☐ Yes ☒ No

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☒ Yes ☐ No Size of gravel:

Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Deschutes Driller's well number

1/4 1/4 Section 6 T. 14S. R. 13E W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing to bottom

Depth drilled 207 ft. Depth of completed well 207 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Overburden	0	24	
Pin hole lava	4	31	
brown cong.	31	65	
Sandstone	65	95	
Black sand with small gravel (Water bearing)	95	207	95

Work started 3-30 1969 Completed 3/17 1969

Date well drilling machine moved off of well 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Forrest Hall Date 3/17, 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 558

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME JACKSON DRILLING
(Person, firm or corporation) (Type or print)

Address REDMOND ORE.

[Signed] Thomas Jackson
(Water Well Contractor)

Contractor's License No. 802 Date 3-17, 1969